

MASSACHUSETTS CLEAN ENERGY CENTER

Clean Energy and Resiliency (CLEAR) Program

Final Report

Winch Park Microgrid Feasibility Study
City of Framingham, MA

Acknowledgment

Willdan Group successfully completed the City of Framingham Winch Park Microgrid Feasibility Study. This project is funded by the Massachusetts Clean Energy Center Clean Energy and Resilience (CLEAR) program. At Willdan, we believe Commonwealth communities' critical infrastructures can become the islands of resiliency. We committed to developing a clear roadmap for local government facilities and used the City of Framingham's critical infrastructures as an early adopter. This roadmap results from months of successful collaboration among community stakeholders, including the City of Framingham department, MassCEC team, Eversource, technology vendors, and Willdan group teams, including Willdan Smart Cities and Willdan Financial Services, Integral Analytics, and E3.

On behalf of the members of this project, Willdan would like to thank Ariel Horowitz, Senior Program Director, Rhys Webb, and Rees Sweeney-Taylor, Net Zero Grid Program Managers, Steve Casey, Eversource Energy, various City of Framingham departments led by Shawn Luz, City of Framingham Sustainability Coordinator for making this work possible. The many tasks of this work could not have been completed without the dedicated effort of Todd Isherwood, Project Manager; Dr. Wei Tian, Lead Engineer; Molly McKay, Managing Partner; and David Nissenson, Principal.

Mehdi Ganji, PhD
Smart Cities Vice President,
Willdan Group
Anaheim, CA 92806



Executive Summary..... 1

1. Introduction 4

2. Project Initiation..... 5

 2.1 Introduction 5

 2.2 Relevant Reports and Background Information..... 5

 2.3 Stakeholder Group Meeting..... 6

 2.4 Critical Asset Assessment 6

 2.4.1 Framingham High School 9

 2.4.2 Fire Station #2..... 12

 2.4.3 A Street Pumping Station 15

 2.5 Electrical and Thermal Infrastructure Resilience 16

 2.6 Project Scope Definition 17

3. Identify Needs 17

 3.1 Relevant Regulations, Definitions, and Assumptions 17

 3.2 Data Collection and Site Assessment..... 19

 3.2.1 Existing Distributed Energy Resources (DERs) 19

 3.2.2 The Building's Current Conditions and Upgrade Plans 20

 3.3 System Data Collection..... 20

 3.3.1 Distribution System (electric, water, communications) 20

 3.3.2 Needs/Requirements During an Emergency..... 21

 3.4 Resilience Index 22

 3.4.1 Critical Loads with Available Supply 22

 3.4.2 Service Delivery During an Interruption..... 22

 3.4.3 Recovering the Service After a Power Outage 23

4. Technical Solutions 24

 4.1 Proposed Microgrid Infrastructure and Operations 25

 4.1.1 Microgrid Infrastructure and Equipment Layout..... 25

 4.1.2 Existing and Planned Infrastructure 26

 4.1.3 Microgrid Operation and Control 27

 4.1.4 Interconnection with Utility Grid..... 28

 4.2 Load Characterization..... 29

 4.2.1 Summary of the WPMRS Loads 29

 4.2.2 Hourly Load Shapes of Each Stakeholder 29

 4.2.3 Load Aggregation for WPMRS Simulation 35

 4.3 Distributed Energy Resources Characterization 36

 4.3.1 Description of Microgrid DERs 36

 4.3.2 Ability of DERs to Serve Load and Provide Resilience..... 42

 4.3.3 Fuel Sources for Fossil Fuel DERs..... 42



- 4.3.4 DER Capabilities 42
- 4.4 Electrical and Thermal Infrastructure Characterization 43
 - 4.4.1 Simplified Electrical and Thermal Infrastructure Diagram 43
 - 4.4.2 WPMRS Meter Consolidation 43
- 4.5 Microgrid and Building Controls Characterization 44
 - 4.5.1 Microgrid Controls Diagram 44
 - 4.5.2 Microgrid Services and Benefits 46
 - 4.5.3 Load Management and Resilience 48
- 4.6 Information Technology (IT)/Telecommunications Infrastructure Characterization 48
 - 4.6.1 IT/Telecommunications Layout Diagram 48
 - 4.6.2 IT/Telecommunications Operation 50
- 4.7 Conclusion 50
- 5. Financial Solutions 51
 - 5.1 Financial and Economic Analysis Objectives 51
 - 5.2 Microgrid Development & Investment Trends 51
 - 5.2.1 History of U.S. Microgrid Development 51
 - 5.2.2 Microgrid Funding Trends 54
 - 5.2.3 Trends in Ownership Structures 55
 - 5.3 Potential Funding Alternatives 55
 - 5.3.1 Direct Funding 55
 - 5.3.2 Third-Party Funding Mechanisms 56
 - 5.3.3 Grants and Capital Enhancements 58
 - 5.4 Operational Benefits, Incentives, and Other Cash-Flow Opportunities 59
 - 5.5 City of Framingham Financing Requirements 59
 - 5.6 Capital Cost Estimate 60
- Other Battery-Related Sizing Considerations 62
 - 5.7 Financial Analysis 63
 - 5.7.1 Key Assumptions 63
 - 5.8 Revenue and Other Financial Inflows 64
 - 5.8.1 Investment Tax Credit 64
 - 5.8.2 MA SMART Solar Program Incentive Payment 64
 - 5.8.3 On-Bill Savings 65
 - 5.8.4 PPA Solar PV Energy Payment from Host to Provider 65
 - 5.8.5 Demand Response (aka Connected Solutions) 65
 - 5.8.6 Clean Peak Energy Credits 65
 - 5.8.7 Depreciation 67
 - 5.9 Expenses and Other Outflows 67
 - 5.9.1 Operations and Maintenance Expenses 67



5.9.2 Host Solar PV Energy Payment to PPA Provider 67

5.9.3 Battery Round-Trip Energy Loss..... 68

5.10 Net Operating Revenues (Stabilized Operations) 68

5.11 Multi-Year Financial Analysis..... 70

5.12 Financial Analysis Conclusions 77

5.13 Financial Sensitivity Analysis 77

6. Conclusion 77

Appendix A: Financial Analysis – Glossary of Terms..... 80

Battery Storage 80

Black Start Support 80

Clean Peak Energy Credits (CPEC)..... 80

Demand Response (Active and Passive) 81

Consolidated Heat and Power (CHP) 82

Curtailed Service Providers (CSP) 82

Curtailed 82

Depreciation 82

Distributed Energy Resource (DER)..... 83

Forward Capacity Market (FCM) Savings..... 83

Frequency Regulation 84

Installed Capacity Reduction (ICAP)..... 84

Investment Tax Credit (ITC) 84

Independent Service Operators (ISO)..... 84

Kilowatt (kW) and Megawatt (MW)..... 85

Kilowatt-hour (kWh) and Megawatt-hour (MWh) 85

Local Property Tax Exemptions 85

Regional Network Services (RNS)..... 86

Reliability 86

Appendix B: State & Federal Grant Programs, Incentives, and Capital Enhancements..... 89



Index of Tables

Table 1. Meeting Summary..... 6

Table 2. Stakeholder Summary..... 7

Table 3. Energy Usage and Cost (FY2020, July-2019 to Jun-2020)..... 7

Table 4. Stakeholder Existing DER Summary 19

Table 5. Priority (or importance) to the Stakeholder (1=highest priority, 5=lowest priority) 21

Table 6. Resilience Expectation 22

Table 7. Load and Backup Generation Capacity 23

Table 8. Resiliency Index..... 23

Table 9. Proposed DER by Facility Site 26

Table 10. WPMRS Average, Peak, and Critical Electrical Loads..... 29

Table 11. Energy Usage and Cost for FHS in Year 2019 30

Table 12. Energy Usage and Cost for FS2 (Year 2021) 32

Table 13. Energy Usage and Cost for PS (Year 2019) 34

Table 14. Price Parameter Used in Simulation 36

Table 15. WPMRS Preliminary Configuration and Cost Analysis Summary 37

Table 16. WPMRS Preliminary Cost Analysis (FHS) 38

Table 17. WPMRS Preliminary Cost Analysis (FS2)..... 39

Table 18. WPMRS Preliminary Cost Analysis (PS)..... 40

Table 19. Summary of Distribution System (Substation, Feeder and Capacity) 43

Table 20. U.S. Microgrid Installation Settings..... 53

Table 21. U.S. Microgrid Total Distributed Energy Resources 53

Table 22. Key Timing and Sizing Assumptions and Estimated Capital Costs..... 62

Table 23. SMART Solar Incentive Rates..... 64

Table 24. CPEC Seasonal and Time of Day Windows 66

Table 25. CPEC Multipliers..... 66

Table 26. Estimated Clean Peak Energy Credits 67

Table 27. Stabilized Year Statement 69

Table 28. Summary of Allocation Assumptions 70

Table 29. Statement of Estimated 20-Year Cash Flow 72

Table 30. 20-Year Cash Flow & Investment Deal Structuring 76



Index of Figures

Figure 1. Winch Park Municipal Resiliency System Concept Configuration (Top chart shows the feeder map, hosting capacity, stakeholders’ locations and suggested DERs; Lower Chart shows the simplified configuration) 3

Figure 2. Winch Park Stakeholders & Existing Backup Generator Locations 8

Figure 3. Potential Resiliency Solution 8

Figure 4. Winch Park Stakeholders Electricity Usage Contribution Percentage 9

Figure 5. FHS 11

Figure 6. FHS Monthly Electricity Usage and Cost in 2019 11

Figure 7. FHS Monthly Natural Gas Usage and Cost in 2019 11

Figure 8. FS2 12

Figure 9. Framingham FS2 Monthly Electricity Usage and Cost in 2021 14

Figure 10. Framingham FS2 Monthly Natural Gas Usage and Cost in 2021 14

Figure 11. PS 15

Figure 12. PS Monthly Natural Gas Usage and Cost in 2019 16

Figure 13. PS Monthly Natural Gas Usage and Cost in 2019 16

Figure 14. Greenhouse Gas Emission Target and Renewable Portfolio Standard 19

Figure 15. Distribution Feeder serving FHS, PS and FS2 21

Figure 16. Winch Park Municipal Resiliency System Proposed DERs Layout 25

Figure 17. Winch Park Municipal Resiliency System Simplified One-line Diagram 26

Figure 18. FHS Hourly Electricity Load Profile (2019) 30

Figure 19. FHS Electricity Load Profile on a Peak Day 30

Figure 20. FHS Monthly Electricity Demand 31

Figure 21. FS2 Estimated Hourly Electricity Load Profile 32

Figure 22. FS2 Estimated Hourly Electricity Load Profile in Peak Load Day 32

Figure 23. PS Annual Hourly Load Profile (2019) 33

Figure 24. PS Hourly Load Profile in Peak Load Day 34

Figure 25. Averaged Hourly Electrical Load Profile in WPMRS 35

Figure 26. Aggregated Averaged Hourly Electrical Load Profile in WPMRS 35

Figure 27. FHS Solar PV Layout (1,060 kW) 41

Figure 28. FS Solar PV Layout (52.8 kW) 41

Figure 29. PS Solar PV Layout (51.2 kW) 42

Figure 30. WPMRS Master Controller Technology Stack (MCTS) 45

Figure 31. WPMRS Proposed Communications and Control Diagram 49

Figure 32. Active U.S. Microgrid Projects by Year of Construction 52

Figure 33. Active U.S. Microgrid Projects by State 52

Figure 34. Volume of Microgrid Project Deals by Funding Source 54

Figure 35. Volume of Microgrid Dollars Invested by Funding Source 55



Acronyms and Abbreviations

ACP	Alternative Compliance Payment
ADA	Americans with Disabilities Act
BOT	Build-Operate-Transfer
BRIC	Building Resilient Infrastructure and Communities
WPMRS	Winch Park Municipal Resiliency System
CIP	Capital Improvement Planning
CLEAR	Clean Energy and Resiliency
C&CB	Capability and Capacity Building
CWSRF	Clean Water State Revolving Fund
CPEC	Clean Peak Energy Credit
CPS	Clean Peak Standard
DER	Distributed Energy Resource
EEA	Energy and Environmental Affairs
ESA	Energy Service Agreement
ESPC	Energy Savings Performance Contract
FCM	Forward Capacity Market
FHS	Framingham High School
FS2	Fire Station #2
GF	General Fund
ICAP	Installed Capacity Reduction
ICP	Installed Capacity Tag
IOU	Investor-Owned Utility
ITC	Investment Tax Credit
IRS	Internal Revenue Service
MassCEC	Massachusetts Clean Energy Center
MACRS	Modified Accelerated Cost Recovery System
MCTS	Microgrid Controller Technology Stack
MEMA	Massachusetts Emergency Management Agency
NG	Natural Gas
OWOW	Office of Wetlands, Oceans, and Watersheds
PACE	Property Assessed Clean Energy
PPA	Power Purchase Agreement
PPP	Public-Private Partnerships
PS	A Street Pumping Station
RNS	Regional Network Services
SMART	Solar Massachusetts Renewable Target
SHMCAP	State Hazard Mitigation and Climate Adaptation Plan
SRF	State Revolving Funds



Executive Summary

The Massachusetts Clean Energy Center (MassCEC) is a state economic development agency dedicated to accelerating the growth of the clean energy sector across the Commonwealth to spur job creation, deliver statewide environmental benefits, and secure long-term economic growth for the people of Massachusetts. MassCEC works to increase the adoption of clean energy while driving down costs and delivering financial, environmental, and economic development benefits to energy users and utility customers across the state.

MassCEC's mission is to accelerate the clean energy and climate solution innovation that is critical to meeting the Commonwealth's climate goals, advancing Massachusetts' position as an international climate leader while growing the state's clean energy economy. Resilience refers to the ability of a system or its components to adapt to changing conditions and withstand and rapidly recover from disruptions, i.e., the ability to recover from a disturbance. The electrical and thermal infrastructure is vulnerable to many phenomena, such as hurricanes, earthquakes, drought, wildfire, flooding, extreme temperatures, etc. Some extreme weather events have become frequent and severe due to climate change.

MassCEC's Clean Energy and Resiliency ("CLEAR") Program is focused on identifying community resiliency projects that reduce GHG emissions, integrate renewable energy sources, and provide energy resilience for critical facilities during outages. The program is a successor to the Community Microgrids Program, which funded fourteen (14) feasibility studies to identify scalable, broadly replicable microgrid business and ownership models to increase microgrid deployment and attract investment. DOE defines a microgrid as "a group of interconnected loads and distributed energy resources within clearly defined electrical boundaries that acts as a single controllable entity for the grid"¹.

This Massachusetts Clean Energy Center's Winch Park Resiliency Community Study evaluated the technical feasibility and commercial/financial opportunities for a municipal resiliency system at Winch Park in the City of Framingham.

The feasibility study evaluated renewable energy installations, in partnership with the public energy and natural gas utility, Eversource Energy, at the following properties ("stakeholders"):

- **Framingham High School (FHS):** FHS was created by combining two schools into one in 1992, with a gross building area of 396,000 square feet. FHS currently enrolls over 2,200 students. FHS has two diesel-powered backup generators, with a total capacity of 1,238 kW, and the onsite fuel can last for four days during grid outages.
- **Fire Station #2 (FS2):** FS2 is the City of Framingham's newest critical facility and went into service on July 17, 2019. FS2 has a 125 kW backup diesel generator with onsite fuel to run 32 hours.
- **The A Street Pumping Station (PS):** The PS on A Street in Framingham was constructed in 2012, and the main purpose of this facility is to transfer/move wastewater downstream, approximately 2,000,000 gallons per day. The PS has two diesel backup generators, with a total capacity of 600 kW, and the onsite fuel can last for four days during grid outages.

The total existing generation capacity is 1,963 kW. The new distributed energy resource generation proposed in this study includes solar plus battery installations at all the stakeholders' locations.

¹ <https://www.energy.gov/sites/prod/files/2016/06/f32/The%20US%20Department%20of%20Energy's%20Microgrid%20Initiative.pdf>



The resiliency-focused community microgrid is proposed to interconnect with the Eversource Energy electrical distribution system to achieve the resiliency, environmental, and economic objectives of the MassCEC CLEAR Program.

The technical solution recommends a solar photovoltaic (PV) capacity of 1,164 kW and battery storage capacity in the range of 165kW/660 MWh (for economic purposes) and 610kW/2,440 MWh (for maximum resiliency purposes). A Combined Heat and Power (CHP) solution is not considered in this report since this CLEAR program is mainly focus on using clean energy to promote community resiliency.

The current annual energy costs and CO₂ emissions for the existing loads are calculated to be \$0.760 thousands and 1,454 metric tons (Electricity: 588 MtCO₂e, Gas: 866MtCO₂e), respectively. This represents the baseline for the proposed microgrid solution. The proposed community microgrid would have a 43.4% annual energy cost saving and 21% annual CO₂ emissions saving compared with the base case mainly contributed by the installed Solar PV. The annual CO₂ emission reduction compared to the base case is 303 metric tons.

The recommended course of action, given reasonable funding limit projections, is to pursue each of the components of the proposed microgrid separately and then eventually tie them together into a community microgrid if conditions warrant. With the federal and state incentives, solar installation is suggested whenever it is available. If an attractive power purchase agreement (PPA) can be developed, then the solar-battery combined system installation will offer economic advantages and environmental benefits.

In order to utilize federal/state tax incentives such as the investment tax credit (ITC) on the proposed solar and battery storage installations, an owner must have a tax liability. The community microgrid could be owned jointly by the stakeholders (in a special-purpose vehicle), a third-party financier, or partly owned by the utility (battery storage). Since all the stakeholders are public or nonprofit entities, a third-party special-purpose entity or Power Purchase Agreement (PPA) owner will likely be developed to own and manage the microgrid. This report refers to the special-purpose entity as the Winch Park Municipal Resiliency System (WPMRS) owner. The microgrid participants will then develop and determine long-term agreements to purchase power from the microgrid owner/operator.

A financial feasibility analysis was conducted to evaluate the City of Framingham's position in a PPA deal structure by measuring the respective capital inflows and outflows to both the City (Host) and the third-party PPA provider. The resulting capital inflows and outflows indicate strong financial positions for both the PPA provider and the City/Host.

The PPA provider's internal rate of return (assuming an all-cash deal) equates to 20.8 percent and a net present value of \$2.27 million, calculated using a discount rate of 8.25%. The city's cash flow over the 20-year term is estimated at \$1.1 million, generating a net present value of \$816,000 when discounted at a rate of 3.0 percent annually.²

Depending upon the availability of funding and the financial situation for the overall project and for each of the stakeholders, Willdan recommends that the proposed resiliency-focused community microgrid proceed with building level microgrid individually at each of the target locations/assets to test the


² The discount rate of 3.0 percent reflects the relatively lower cost of municipal capital from the perspective of the City of Framingham in comparison to private commercial rates.



technical and economic viability of the microgrid power that would be subsequently integrated into a community microgrid.

Figure 1 is the final concept of the proposed community microgrid, which is the result of the detailed assessment of the existing system and consideration of the different stakeholders’ needs, requirements, goals, and operational constraints. The applied methodology and strategy will be fully elaborated in the following sections.

Figure 1. Winch Park Municipal Resiliency System Concept Configuration (Top chart shows the feeder map, hosting capacity, stakeholders’ locations and suggested DERs; Lower Chart shows the simplified configuration)



As shown in Figure 1, all the stakeholder locations are fed by the 13.8kV feeder. This configuration served to reduce the complexity of community microgrid islanding and interconnection.



1. Introduction

The City of Framingham (the City) recognizes the escalating threat that climate change poses to its critical facilities and the greater community that it serves. Natural hazards have already resulted in emergency events such as utility outages, highlighting local infrastructure vulnerabilities. The current energy distribution system contributes to greenhouse gas emissions and leads to higher energy costs. In 2018, the City hosted a Community Resilience Building Workshop through the Municipal Vulnerability Preparedness Program that identified energy resiliency improvements as one of its most crucial priorities. The City has already taken steps towards addressing these climate threats by creating a Sustainability Committee and Internal Energy Working Group. The City also has an energy efficiency outreach program, participates in an energy demand-response program, and is developing municipal solar PV projects. The City is also currently working on updating its Multiple Hazard Mitigation Plan. The MassCEC CLEAR study hopes to provide another opportunity to address community energy resiliency.

The goal of this CLEAR study is to report on the site assessment, identify resiliency needs, develop preliminary technical design and configuration, assess the commercial and financial feasibility and perform the cost-benefit analysis for a community microgrid anchored at Winch Park in the City of Framingham. Willdan Energy Solutions (Willdan) is the lead technical consultant retained by MassCEC to perform the analysis and navigate the study team through the community microgrid evaluation. The CLEAR study team includes Willdan, FHS, FS2, PS, and Eversource Energy.

The primary goals of the study are to determine how a microgrid system at this grouped location could (1) increase the fuel diversity of municipal facilities to improve the resiliency of their critical infrastructure, (2) achieve greater integration of clean energy technologies to reduce greenhouse gas emissions, and (3) cut energy costs.

The MassCEC CLEAR study seeks to build on the resilience-focused energy planning programming started during the MassCEC’s Community Microgrid Feasibility Studies. Identifying technical and investment solutions will enable critical loads to "ride through" interruptions in grid service and save productivity losses.

Following the execution of the proposed work plan and scope of work, this final feasibility study report summarizes the findings from all tasks and is organized as follows:

ECONOMIC BENEFITS OF RESILIENCY

Energy resiliency is achieved through the preparation, operation, and subsequent recovery from extreme weather and other prolonged adverse events that disrupt the provision of reliable power.

Businesses rely on a regular supply of energy and contingency measures in the event of a power failure. Causes of resiliency issues include power surges, weather, natural disasters, accidents, equipment failure, and human operational error.

Businesses with access to reliable energy are better insulated against energy price increases or fluctuations in supply. Resiliency planning enables businesses to avoid shutdowns of important processes that impact their delivery of goods or services.

While most power outages are short-term in nature, there is a clear trend in the increasing number of large-scale natural weather events that trigger broader, longer-term disruptions.

Critical public health and safety operations such as health care, senior centers, and emergency services particularly rely on resilient energy systems to protect their communities.

The study will create the body of data on costs and system designs needed to create resilient facilities. An additional goal is to provide a replicable pathway for customers to assist utilities in outage recovery events. The study may also identify barriers, therefore helping inform future energy-related policy decisions.



- Section 2 presents the project initiation and site assessment (Task 1).
- Section 3 identifies the resiliency needs or requirements of each of the stakeholders (Task 2).
- Section 4 presents the preliminary technical design costs and configuration (Task 3).
- Section 5 discusses the commercial and financial feasibility assessment as well as the cost-benefit analysis (Task 4).
- Section 6 summarizes the major findings and recommendations of the feasibility study (Task 5).

2. Project Initiation

2.1 Introduction

The proposed Winch Park Community Resiliency System incorporates municipal facilities and involves the Framingham Public Schools, Framingham Fire Department, and Framingham Public Works Department.

This section reviews and describes the existing site assets, including energy usage, generation resources, etc. that were applied in the proposed resiliency study. The assessment included a review of the existing documents such as the City's Municipal Vulnerability Plan (MVP) program, the Hazard Mitigation Plan, maps, and building layouts. Generation resource load information, energy demand uses and requirements, and preferred microgrid characteristics provided a baseline for this MassCEC CLEAR study.

2.2 Relevant Reports and Background Information

The technical team has received and reviewed the following reports/documents related to this resiliency study.

1. Town of Framingham Multiple Hazard Mitigation Plan (2017 Update)³
2. City of Framingham-Community Resilience Building Workshop Summary of Findings (May 2019)⁴
3. Town of Framingham Master Plan Part 2: Master Land Use Plan (September 2014)⁵
4. Winch Park Flood Map⁶
5. City of Framingham Municipal Energy Initiatives⁷
6. Framingham Public School Emergency Response Plan (February 2016)⁸

Flood, wind, fire, earthquake⁹, winter storms/blizzards, and extreme temperatures are identified as the primary potential hazards that might impact the resilience of this area's energy system.

The data and information identified in this section will be integrated with the technical and financial solutions in later tasks.

³ https://www.framinghamma.gov/DocumentCenter/View/27116/FINAL-MHMP-Update-2017_04072017

⁴ https://www.framinghamma.gov/DocumentCenter/View/35478/English_EEA_Report_Framingham

⁵ <https://www.framinghamma.gov/DocumentCenter/View/5236/Master-Plan-Update-Sept-2012?bidId=>

⁶ www.resilientma.org/map

⁷ <https://www.framinghamma.gov/2743/Municipal-Programs-Initiatives>

⁸ <https://www.framingham.k12.ma.us/cms/lib/MA01907569/Centricity/Domain/68/Emergency%20Response%20Plan%20SY14-15%20revision.doc>

⁹ https://www.framinghamma.gov/DocumentCenter/View/27116/FINAL-MHMP-Update-2017_04072017



2.3 Stakeholder Group Meeting

The technical team has conducted several stakeholder meetings, including meetings with the local electric utility provider (Eversource Energy) within the project period. The technical team met with the stakeholders two times during Task 1. The stakeholder meetings are summarized in **Table 1**.

Table 1. Meeting Summary

Meeting	Date	Participant	Topic
Stakeholder Meeting-01	07/02/2020	MassCEC, City of Framingham, Public Works Department (PWD), Framingham Fire Department (FFP), Framingham A Street Pumping Station (PS), Willdan Group	Introduction meeting and kickoff
Stakeholder Meeting-02	09/24/2020	MassCEC, Housing Authority, City of Framingham, PWD, FFD, FPS, Willdan Group	All-stakeholder meeting
Stakeholder Meeting-03	10/29/2020	MassCEC, Housing Authority, City of Framingham, PWD, FFD, FPS, Willdan Group	RFI and resiliency survey review, and questions from the Framingham MVP
Stakeholder Meeting-04	03/10/2021	City of Framingham, Willdan Group	Financial stakeholders meeting
Stakeholder Meeting-05	04/20/2021-05/20/2021	MassCEC, Housing Authority, City of Framingham, PWD, FFD, FPS, Willdan Group	Series of meetings for a high-level overview of the potential solution
Stakeholder Meeting-06	08/03/2021	City of Framingham, Willdan Group	Second financial stakeholders meeting
Eversource-Willdan Meeting-01	11/10/2020	MassCEC, Eversource Energy, Willdan Group	RFI review and discussion
Eversource-Willdan Meeting-02	01/22/2021	Eversource Energy, Willdan Group	RFI review and discussion
Eversource-Willdan Meeting-03	05/19/2021	MassCEC, Eversource Energy, Willdan Group	Overview of the resiliency expectation, planning and operation, community microgrid configuration.
Eversource-Willdan Meeting-04	10/01/2021	MassCEC, Eversource Energy, Willdan Group	Review refined concept of the technical solution at Winch Park

2.4 Critical Asset Assessment

A summary of the stakeholders' information is listed in **Table 2**. Each stakeholder location and its existing generation assets are shown in **Figure 2**. The potential locations for new generation assets for each location are identified in **Figure 3**. The electricity usage percentage for each of the sites is shown in **Figure 4**.



Table 2. Stakeholder Summary

Stakeholder	Critical Facility	Building Sq. Ft.	Annual Electricity Usage (kWh) ¹⁰	Backup Generation (kW)
FHS	Tier 1 ¹¹	396,000	2,131,080	1,238
FS2	Tier 1	9,282	134,000	125
PS	Tier 1	9,710	623,272	600

The summary of annual energy usage and cost is presented in **Table 3**. The monthly use and cost for both natural gas and electricity are presented in Section 2. FHS and PS have hourly granular interval electricity load data. Only monthly bill data, including use and cost, are available for FS2.

Table 3. Energy Usage and Cost (FY2020, July-2019 to Jun-2020)

Stakeholder	Annual Gas Usage (Therms)	Annual Gas Cost (\$)	Annual Electricity Usage (kWh)	Annual Electricity Cost (\$)	Hourly Electricity Load Data
FHS	140,184	124,076	2,131,080	472,565	Available
FS2	7,756	9,274	134,000	23,763	Not Available
PS	15,465	13,311	623,272	117,425	Available

The technical team visited the three sites and toured the Winch Park study site's surrounding area on November 24, 2020. Todd Isherwood (Willdan) and Shawn Luz (City of Framingham) met with personnel from the City of Framingham's Public School, Public Works Department, and Fire Department. FHS, which contributes 74% of the total electricity consumption, is the largest electricity user in the group.

¹⁰ MassCEC CLEAR Program Energy Data (3-3-22).xlsx, 2021 usage data is applied for Fire Station #2 due to meter issue in 2019, and 2019 data are applied here for the rest two stakeholders

¹¹ Tier 1 facilities are facilities that are capable of causing the greatest adverse consequences if disrupted or destroyed, as defined by the Homeland Infrastructure Threat and Risk Analysis Center (HITRAC).



Figure 2. Winch Park Stakeholders & Existing Backup Generator Locations




Source: City of Framingham, 2021

Figure 3. Potential Resiliency Solution



Source: City of Framingham, MA, 2021

Figure 4. Winch Park Stakeholders Electricity Usage Contribution Percentage



2.4.1 Framingham High School

FHS pictured in **Figure 5**, was created by combining two schools into one in 1992. From 2001 through 2007, a significant renovation and construction project was undertaken to add a library, science wings, and a mechanical room to the existing structure.

The campus contains 396,000 square feet of roof space and is situated on 44.35 acres of land. The grounds include a synthetic football/soccer field, a field hockey field, a tennis court, and multiple ball fields at the front of the school, which are owned and maintained by the Parks and Recreation Department. The parking lot houses over 463 vehicle parking stalls. The building was designed on multiple levels with a two-story spread footprint¹² and three enclosed courtyards. Two elevators comply with the Americans with Disabilities Act (ADA), fire, and building code requirements. The school has 90 full classrooms with a design capacity of 2,086 students. The current student enrollment is 2,268.

The building has two separate boiler rooms, two generator rooms, and multiple mechanical rooms. There are dual fuel gas-fired boilers and water heaters, diesel-fired generators, and #2 oil stored in an underground tank for firing boilers on oil in an emergency. Roof-top air handling units and cooling provide cooling for half of the building. The other half is piped and can be expanded with cooling if a chiller and cooling tower is installed. As of this report, the whole building except for the cafeteria is air-conditioned after the School Department’s recent project; however, the electricity consumption and demand are not reflected in the historical electricity data used in the study in this report. FHS is a

¹² Framingham High School - School Data Book.pdf



qualified Massachusetts Emergency Management Agency (MEMA) shelter because underground fuel storage tanks provide an independent fuel source for the backup generators and boilers.

The following site observations were compiled from a site walkthrough and conversations with Tim Rivers of the Framingham School Department.

- The school has two main electrical rooms. One room is below grade and is vulnerable to rainwater flooding during severe storms.
- Three natural gas-fired boilers for heating are in a mechanical room below grade. They are vulnerable to rainwater flooding during severe storms.
- Two diesel-powered backup generators (668 kW+570 kW) have enough fuel to run for four days. The generators back up circulating pumps for the boilers, lights, data closets, walk-in coolers, and computer room. Two diesel storage tanks have an approximately 3,000-gallon capacity each.
- Two 300-ton chillers for cooling serve the entire complex and have recently been installed. The cooling equipment includes 12 heat recovery units, 8 rooftop units, and air-handling units. A few fan coil units are dispersed throughout the campus in various classrooms.
- The main computer room hosts a server farm that supports one-half of the public school's IT network. This room has split-system cooling that is backed up by the generator.
- The facility is considered a warming center only.
- The auditorium has mechanical cooling and gas-fired heating and seats 696 people. The system does not appear to be backed up on the generator.
- The building management system uses American Energy Manager (AEM) Controls. These controls are the standard across the school's real estate portfolio. The controls can be accessed remotely (off-site)
- The site and building lights in the school have been retrofitted to LED.
- All locations identified by the City for solar canopies in parking lots have potential. An additional area for solar PV is on the school roofs.
- There is plenty of space for outdoor energy storage/battery locations.
- Combined heat and power (CHP) is a potential option for this location.



Figure 5. FHS



The monthly electricity/gas usage and cost are shown in **Figure 6** and **Figure 7**, respectively. The monthly average electricity usage and cost are 117,590 kWh and \$39,380. The monthly gas usage and cost are 11,682 therms and \$10,340. The average electricity demand is 243 kW.

Figure 6. FHS Monthly Electricity Usage and Cost in 2019





Figure 7. FHS Monthly Natural Gas Usage and Cost in 2019





2.4.2 Fire Station #2

Figure 8. FS2



FS2, shown in **Figure 8**, is the City of Framingham's newest critical facility and went into service on July 17, 2019. The following site observations were compiled from a site walkthrough and conversations with Dana Haagensen of the Framingham Fire Department.

- The primary purpose of this facility is emergency response (fire and EMT services)
- Two natural gas-fired boilers and a domestic water heater are in a mechanical room.
- Heat pumps provide cooling and supplemental heating.
- One diesel-powered backup generator (125 kW) has enough fuel to run 32 hours. The department has a transfer vehicle to supply diesel from one of their firehouse diesel storage tanks. The entire facility is backed up.
- There are no automatic garage door closers, however, trucks are outfitted with door controls. Open doors have contributed to high energy use to mitigate ambient air temperature entering the garage if the doors are not closed.
- This facility has a residential use, including sleeping quarters, men's and women's locker rooms and showers, kitchen, laundry, gym, and lounge/entertainment areas.
- The building management system uses AEM Controls.
- The building was constructed in 2019.
- The roof has the potential for solar PV at this location (solar-ready roof with conduit).
- Limited real estate may be available to serve as an outdoor energy storage/battery location. The potential site is between the fire station and the adjacent A Street Pumping facility.
- This site's electrical data has just become available in May of 2020 due to an Eversource error in the metering configuration.

The total electricity usage in year 2021 is 134,000 kWh, and the total bill is \$23,763. The average monthly electricity usage and bill for this period are 11,167kWh and \$1,980, respectively. The average electricity and natural costs are \$0.177/kWh and \$1.19/therm for this site. The monthly electricity usage and cost are shown in **Figure 9**. Monthly natural gas usage and cost are shown in **Figure 10**. The average electricity demand is 15.3 kW.



Figure 9. Framingham FS2 Monthly Electricity Usage and Cost in 2021





Figure 10. Framingham FS2 Monthly Natural Gas Usage and Cost in 2021



2.4.3 A Street Pumping Station

Figure 11. PS



Figure 11 shows the PS. The following site observations were compiled from a site walkthrough and conversations with Peter Lampasona and Steve Leone of the Framingham Public Works Department.

- The primary purpose of this facility is to transfer/move wastewater downstream (approximately 2,000,000 gallons per day). The secondary purpose includes a maintenance garage for the service department vehicles.
- The facility is equipped to serve as a remote command center for half of the City during severe storms (blizzards) and other emergency events that require City coordination.
- There are typically very few personnel onsite.
- Two natural gas-fired boilers for heating are in a mechanical room.
- Heat pumps provide cooling and supplemental heating.
- Two diesel-powered backup generators (300 kW+300 kW) have enough fuel to run for four days. The generators back up the entire facility. One diesel storage tank has an approximately 5,000-gallon capacity but is only filled to 3,000 gallons at a time.
- There are five portable diesel-fired generators stored onsite for use around the City as necessary.
- The odor mitigation system is a critical operation.
- The computer room onsite contains a server farm that supports half of the City's IT services.
- The building management system uses AEM Controls.
- The building was constructed in 2012; however, T-5 fluorescent bulbs and incandescent lamps exist onsite.
- Limited real estate may be available to serve as an outdoor energy storage/battery location.
- Combined heat and power is a potential option for this location.

The monthly electricity/gas usage and cost are shown in **Figure 12** and **Figure 13**, respectively. The monthly average electricity usage and cost are 53,322 kWh and \$9,955. The monthly gas usage and cost are 1,050 therms and \$879, respectively. The average electricity demand is 73 kW.

Figure 12. PS Monthly Natural Gas Usage and Cost in 2019





Figure 13. PS Monthly Natural Gas Usage and Cost in 2019



2.5 Electrical and Thermal Infrastructure Resilience

In the current condition, the resilience of the stakeholders is tied to the utility grid or existing emergency backup generators. For those critical facilities such as the fire and security systems (which already have an



emergency backup battery/generator), the duration of running the emergency backup generator to serve the connected load would depend on the available amount of fuel in the tank or the available delivery service.

Snowstorms and peak loads in the winter season could cause damage or outages to the overhead system in the City of Framingham. Also, heat waves in summer could affect distribution line conductor sags and any equipment that needs to be cooled off, such as transformers, battery storage, etc. A wind gust could cause tower/pole and conductor faults due to trees falling. It would also be necessary to upgrade designs and focus more on emergency planning and restoration. For example, Hurricane Sandy occurred in 2012, which caused a widespread blackout of the power system on the eastern seaboard and left millions of homes in the dark for periods ranging from a couple of hours to a few weeks. Natural gas disruptions are less likely than electricity disruptions; however, it is relatively more difficult to recover from natural gas system failure-driven outages than electric systems because of the difficulty in locating and repairing the underground leakages. The extreme weather would affect both individual equipment failure and system operations. The damage from such events can impose large costs on the distribution system and have a severe impact on the local economies.

A community microgrid would solve the constraints by providing additional capacity and resiliency to the Eversource electric system. The 13.8 kW feeder is overhead. The majority of the existing distribution equipment within each stakeholder location is on the ground and is highly sensitive to flooding. The equipment that needs to be upgraded should be evaluated when design specifications are created for the infrastructure upgrades. Special attention should be paid to flood risk and reliability in severe weather. Controls and communication will improve resilience during weather events and in advance by providing flags and warnings for preventative maintenance and minor malfunctions before they lead to more significant events that can cause grid impacts.

2.6 Project Scope Definition

We believe that a community resilience plan requires implementing a holistic and integrated community analysis, including the cyber-physical infrastructure sector's vulnerability. However, considering the statement of work approved by MassCEC and the City of Framingham MVP information, we will focus on this community's energy infrastructure resilience. Additionally, we will evaluate different microgrid configuration options for the project facilities (Campus, Community, Utility-Owned/Operated).

3. Identify Needs

The goals of this section (Task 2) are to report the identified needs for an energy resiliency solution utilizing a community microgrid. This task included reviewing relevant regulations, definitions, and assumptions. Furthermore, the data collection process and site assessment have been provided. The existing electrical distribution configuration and associated system metrics are outlined. Finally, the resilience indexes that have been created will help define the technical solution's preferred resiliency characteristics in the following section (Task 3).

3.1 Relevant Regulations, Definitions, and Assumptions

Framingham, Massachusetts, was incorporated as a town on June 25, 1700; it then adopted a home rule charter and transitioned to a City on January 1, 2018. The branches of government include the executive



(Mayor) and legislative (City Council). Also, an elected School Committee oversees the nine districts in Framingham.

Framingham’s 2020 Strategic Plan has adopted the Commonwealth’s goal of achieving net zero emissions by 2050. The City’s Sustainability Coordinator is closely monitoring the Commonwealth’s 2050 Decarbonization Roadmap that includes achieving at least an 85% emissions reduction below 1990 levels. Supporting the City, the constituent-based Sustainability Committee will consider practical new programs and policies as well as public engagement and outreach activities that seek to address environmental, resource, and energy challenges. In coordination with the feedback from the Sustainability Committee, City officials are seeking to develop a Climate Action Plan that will serve as a comprehensive and holistic blueprint to reduce greenhouse gas emissions and improve local resiliency.

Framingham has had a history of addressing energy and climate challenges, even before becoming a City. In December of 2013, Framingham received its Green Community designation from the Commonwealth of Massachusetts’ Department of Energy Resources. The Green Communities Program provides municipalities with technical and financial support to cut municipal energy consumption by 20 percent over five years. Other criteria outlined in the Green Communities Act include greenhouse gas emissions reduction, which addresses climate change. While the City has not achieved a 20% reduction of energy use over the five-year target from a 2011 baseline, this study for adopting community microgrids accelerates the pace toward that target. Community microgrids that utilize both renewable energy sources and energy storage dispatch have reduced the need for traditionally sourced public utility-supplied electricity and create efficiencies at many levels. As noted in Section 2, Framingham’s vulnerabilities to climate change are grounded in their Municipal Vulnerability Preparedness Program report.

In 2020, the City of Framingham held a Community Resilience Building (CRB) Workshop that identified improvements to energy resiliency as one of the City’s most critical priorities. CRB Workshop identified the following key action steps:

- Prioritize energy efficiency as a reliability asset to reduce vulnerability to extreme weather and other events
- Analyze opportunities for energy storage at municipal facilities
- Conduct a microgrid feasibility study to identify alternatives with minimal upfront capital outlays and no ongoing maintenance requirements.


A proposed multi-faceted community energy resiliency project was developed following the CRB workshop, prioritizing facilities that provide emergency shelter and response, critical wastewater infrastructure, and public housing assets for the community’s vulnerable lower-income residents.

The City has leveraged several energy programs that provide energy incentives and savings. For example, the Green Communities Competitive Grant Program helped Framingham implement an Energy Savings Performance Contract (ESPC) for LED retrofits, HVAC system renovations, and equipment upgrades. MassSave energy efficiency programs administered by Eversource have been leveraged. The City will also use Eversource’s net-meter provisions for solar PV installed at the new Fuller Middle School. Eversource is also supporting infrastructure for electric vehicle charging stations. Finally, the City currently has a power purchase agreement (PPA) for almost 2 MW of solar located on the roof of a privately-owned shopping center in Framingham. It is assumed that all of these programs and associated procurements will help define the community microgrid as it was developed in Sections 4 (Task 3) and 5 (Task 4) of this study.



As shown below¹³, through the Renewable Portfolio Standard, Massachusetts will require that 38.96% of electricity must come from qualifying renewable facilities by 2025. Furthermore, the MA Greenhouse Gas Emission Targets require 78% GHG emission reduction by 2050 (Figure 14). Currently, Eversource grid emissions intensity in the City of Framingham is around 36%.

Figure 14. Greenhouse Gas Emission Target and Renewable Portfolio Standard



The study will need to consider the barriers associated with developing a community-based microgrid. Currently, behind-the-meter generation and use are allowed in the regulatory environment. Some export of generation to Eversource's grid is allowed with approved precursory engineering studies. However, energy exchanges and financial transactions between different building owners in front of the meter are not allowed under current regulations. The City currently purchases its electricity from Eversource, an investor-owned utility (IOU). Eversource owns the franchise rights to deliver electric and natural gas energy in Framingham. The Commonwealth's Department of Public Utilities oversees safety concerns and rate-making policy for customer cost by Eversource. This study works toward solutions within the regulatory environment and potentially offers alternatives for front-of-the-meter technical solutions for future consideration.

3.2 Data Collection and Site Assessment

3.2.1 Existing Distributed Energy Resources (DERs)

The three stakeholders' locations, existing generation assets, and potential areas for new distributed energy resources (DERs) identified by the City have been presented in Section 2. The existing DER summary information for the three stakeholders is listed in Table 4.

Table 4. Stakeholder Existing DER Summary

Stakeholder	Backup Generation (kW)	Fuel Tank Capacity (Gallon)	Generator Detail
-------------	------------------------	-----------------------------	------------------

¹³ Eversource Energy A Sustainable Investment Opportunity, November 2019



FHS	1,238	Two tanks, underground, a total of 3,000 gallons, for four day's usage	One 668 kW and one 570 kW diesel backup generator
FS2	125	Enough fuel to run for 32 hours.	Transfer vehicle to supply diesel from one of their firehouse diesel storage tanks
PS	600	5,000 gallons, suitable for four days' usage	Two 300kW diesel generators, five mobile generators
Total	1,963	8,000 gallons	Total of five diesel backup generators and five mobile backup generators

3.2.2 The Building's Current Conditions and Upgrade Plans

FHS is a qualified MEMA shelter, and underground fuel storage tanks provide an independent fuel source for the backup generators and boilers. The roof has the potential for a 46-kW solar PV (solar-ready roof with conduit). The detailed condition of these three sites is presented in Section 1. There is no major upgrade plan at the stakeholders' locations as of the publication date of this report.

3.3 System Data Collection

3.3.1 Distribution System (electric, water, communications)

As shown in **Figure 15**, all three stakeholders are served by the same 13.8 kV feeder (433-H4). This 13.8 kV feeder is eligible to connect with the DER or microgrid. The historical reliability index for this feeder is CAIDI at 360 and SAIFI¹⁴ at 2.012, respectively, smaller CAIDI and SAIFI index indicate that the customers experienced less outages with high reliable electricity supply.


With the information provided by Eversource regarding the gas delivery system in this project area, gas pipe sizes range from 2 inches to 6 inches. The gas delivery system has sufficient capacity for the installed services. The system is very reliable due to the underground design. Outages are minimized from weather or extreme conditions compared to above-ground utilities.

The water system information, natural gas pipeline and communication system were not available and were not studied. This report focused on the energy system, and the three stakeholders' interconnection configuration with the feeder is shown in **Figure 15** for FHS, FS2, and the PS (433-H4, 13.8 kV).

¹⁴ Customer Average Interruption Duration Index (CAIDI) and System Average Interruption Frequency Index (SAIFI) are a reliability index commonly used by electric power utilities. CAIDI gives the average outage duration that any given customer would experience. CAIDI can also be viewed as the average restoration time. SAIFI is the average number of interruptions that a customer would experience.



Figure 15. Distribution Feeder serving FHS, PS and FS2



3.3.2 Needs/Requirements During an Emergency

The information below was collected from the responses to the questionnaires sent to each of the stakeholders. The priority (or importance) of each stakeholder’s resilience expectations is presented in Table 5.

Table 5. Priority (or importance) to the Stakeholder (1=highest priority, 5=lowest priority)

Stakeholder	Resiliency	Climate Goals	Economics	Operations	Community
FHS	4	3	1	2	5
FS2	1	4	2	3	5
PS	1	4	2	5	3

*Resiliency: Guarantees a better energy supply, in addition to the existing diesel generator

*Climate Goals: Reduces Community GHG Emissions Portfolio

*Economics: Rebates and incentives, unlocking energy services & benefits, minimizing the cost of the development, procurement, and operation & maintenance of energy assets

*Operations: Maximizes the value of existing use/unused energy resources and staff

*Community: Supports other stakeholders’ critical operations & business continuity

Framingham High School

A campus/community microgrid is expected to improve the power supply’s reliability and stability to avoid power fluctuations and outages. The proposed solar PV combined battery storage-based microgrid system would also help the school to curtail its energy bill by reducing the energy cost and demand charge.

Fire Station #2

A campus/community microgrid is expected to add additional layers of resiliency to the Fire Department’s energy supply, which benefits from keeping operations running 24/7, even during weather events/natural disasters.

A Street Pumping Station



The proposed microgrid could reduce the electricity costs to run the wastewater pump station and support resiliency in the event of a significant disaster. The operational staff in the pump station prefer simple and reliable operation, specifically during emergency conditions. They express a concern that the added microgrid system would increase the system and operational complexity and would like to own and operate all the components installed on their site.

Another benefit would be installing new replacement capital equipment as part of this project to reduce the department’s overall capital project costs.

3.4 Resilience Index

3.4.1 Critical Loads with Available Supply

All the stakeholder locations are identified as “Tier 1” facilities which can cause the greatest adverse consequences if disrupted or destroyed. The resilience expectation for each of the stakeholders is presented in **Table 6**, based on information provided in the questionnaires. Approximate electrical loads of 30% at the FHS are critical. All the loads of FS2 and the PS are critical loads.

Table 6. Resilience Expectation¹⁵

Stakeholder	Disruption Delay	Maximum Operation Degradation Level	Maximum Disruption Duration Tolerance	Recovery Response Time
FHS	Hours	70%	Hours	Minutes
FS2	None	0%	None	None
PS	Seconds	0%	Minutes	Minutes to Hours

3.4.2 Service Delivery During an Interruption

The peak load, average load, and backup generation capacity of these sites are shown in **Table 7**. All the stakeholders have enough backup generation capacity to cover their peak load if the backup generators can be online as designed and be configured to serve all their loads.

¹⁵ Stakeholder Resiliency Expectation Survey. Disruption delay: expectation of electrify service restoration time after grid outage. Maximum Operation Degradation Level: possible of percent of possible load curtailment. Maximum Disruption Duration Tolerance: the maximum limit of outage time, significant damage or loss could be caused if outage time surpass this limit. Recovery Response Time: Expected time of service to be restored.



Table 7. Load and Backup Generation Capacity

Stakeholder	Peak Load (kW)	Averaged Load (kW)	Backup Generation (kW)	Backup Fuel
FHS	813	247	1,238	4 Days
FS2	28	13	125	32 Hours
PS	134	73	600	4 Days

3.4.3 Recovering the Service After a Power Outage

The recovery procedures after a power outage were collected from each of the stakeholders and are discussed in this section.

Framingham High School

A power failure usually ends up burning out the 3-phase motors. It can be a safety issue for people occupying the building to exit if emergency generators do not come online as designed. The building automation systems need to be physically reset to get the heating system running again during the winter months after the power outage.

Fire Station #2

The most significant factor in energy disruptions has been the impact of the momentary loss and recovery of power on sensitive electronics/system controls. These brief power changes have wreaked havoc on modern systems with computer-based controls. Long-term power losses would be a concern because the department would need to relocate resources to another station that would impact response times in the district of the outage.

A Street Pumping Station

Typical power outages generally do not impact the site’s operations significantly due to its backup generation resources. The unexpected failure of critical components in the electrical distribution system onsite has impacted the regular operation significantly.

A resiliency index weight table is defined to guide the simulation and analysis for different scenarios in later tasks, shown in Table 8.

Table 8. Resiliency Index

Islanding Days	Load Curtailment	Resiliency Weight
7	0-30%	100%-89.41%
6	0-30%	86.76%-76.18%
5	0-30%	73.53%-62.94%
4	0-30%	49.71%-73.53%
3	0-30%	47.06%-36.47%
2	0-30%	33.82%-23.24%
1	0-30%	20.59%-10%



Resiliency weight is defined based on the following criteria:

- The maximum number of days that critical facility capacity is being responded to during the grid outage duration.
- The maximum level of a critical facility that can be served.
- The capability of serving critical facilities with no load curtailment for seven days (as the customer’s requirement) is defined as 100% resiliency.

The customer would not experience any power disruption in this best resiliency scenario, i.e., 100% resiliency weight, in which 100% of load would be continually served for up to 7 days without interruptions or curtailments. Load curtailment is the disconnection of predetermined non-critical loads, such as non-emergency lighting, that can be programmed into building controllers for automated shut off in the event of an emergency. The capability of serving 70% critical facilities for one day is defined as 10% resiliency weight, i.e., the 70% customer’s load could be continually served for one day at the 10% resiliency weight. The resiliency weight would be 20.59% if all the loads (100% of the loads or customers) were continually served for up to one day. The higher resiliency scenario would require more backup generation capacity, resulting in a large upfront investment cost. The resiliency index would be considered based on the resiliency expectation questionnaire or the current onsite backup fuel volume. Suppose the resiliency information not provided or available. In that case, the resiliency of 3 day (or 72 hours) supporting the expected critical load are generally applied..

4. Technical Solutions

The goal of the technical analysis (Task 3) is to propose a preliminary technical design and system configuration for the proposed community microgrid anchored at Winch Park in the City of Framingham, MA, in accordance with the findings of the site assessment and characteristics identified in Section 3 (Task 2).

A preliminary assessment of the system was conducted, and multiple preliminary solutions were presented to key stakeholders at the microgrid team meeting. One solution was developed further into a technical design and system configuration based on stakeholder requirements and feasibility.



4.1 Proposed Microgrid Infrastructure and Operations

4.1.1 Microgrid Infrastructure and Equipment Layout


Figure 16. Winch Park Municipal Resiliency System Proposed DERs Layout



The layout of the proposed new distributed generation resources (DERs), such as solar PV and batteries, are shown in **Figure 16**. The backup generators shown in **Table 7** are used mainly for emergency backup purposes and are not shown in this figure. Stakeholder solar and battery locations are identified by a red label above the solar and battery icons. A CHP solution is not considered in this technical solution since this CLEAR program is focus on using clean energy to promote community resiliency. The CHP solution would need further study of the heating load pattern and electricity to heating load ratio. The Point of Common Coupling (PCC) or interconnection point with the utility is identified by a red rectangle with a cross inside. If each of stakeholder would operates their own microgrid, the PCC for each of the sites will be located at their resepective main breaker or meter. The proposed community microgrid is a networked microgrid cluster, in which each of the stakeholder locations is designed as a microgrid and can run in islanded mode independently.

The simplified one-line diagram of the proposed microgrid is seen in **Figure 17**. The microgrid is fed from Eversource’s 13.8kV distribution network. Solar and batteries are connected to or isolated from various building loads, depending on location. In this representative diagram, each of the stakeholders can run in an islanded/grid-connected mode independently. During a power outage, the three stakeholders would be connected through the optimally coordinated dispatch of loads and charging/discharging of the battery and running as community microgrids.

Figure 17. Winch Park Municipal Resiliency System Simplified One-line Diagram



All the stakeholders are connected to the same 13.8kV feeder, which reduces the community microgrid islanding and interconnection complexity.

4.1.2 Existing and Planned Infrastructure

Based on the information provided by the City and stakeholders, a total of 1963 kW diesel/natural gas backup generator has been or will be installed across the three sites. The existing/planned backup generation assets are summarized in **Table 7**.

The existing backup generators would only be running during islanded mode for extensive hours of self-supply. Hourly granular data are available for FHS and PS as of the publication date of this report.

The proposed solar and batteries are seen in **Table 9** and consist of solar and storage systems designed to maximize solar onsite, providing backup and fast response with the batteries. Both resiliency and economic-oriented solutions are studied. The proposed DERs would be able to work in both grid-connected and islanded modes. A DER optimization planning tool developed by Willdan has applied the optimal DER mix while satisfying stakeholders’ resiliency and economic expectation. The electricity tariff, hourly load shape, potential spaces for solar installation, historical weather data, etc., are considered in the model and simulation. In general, the resiliency-oriented solution would provide a 6-72 hours ride-through for the critical loads of each stakeholder during a grid outage, resulting in a high investment cost and a longer payback period. The economical solution results in a smaller battery recommendation, a lower investment cost, and a shorter payback time, which would be favored by a PPA contractor, as studied in the financial assessment (Section 5), while results in a shorter period of islanding capacity (1 hour for PS, 10 hours for FS2 and 24 hours for FHS depending on clean energy only).

Table 9. Proposed DER by Facility Site

Location	Solar Capacity (kW)	Energy Storage (kW/kWh) (Resiliency)	Energy Storage (kW/kWh) (Economic)
FHS	1,060	500/2,000	250/500
PS	51	60/240	15/60
FS2	53	50/200	25/100
Total	1,164	610/2,440	290/660



Additional infrastructure, including electrical and thermal distribution, building and grid controls, and IT/telecommunications equipment, will be added to support the installation of the generation resources above, described in their respective sections of this report.

4.1.3 Microgrid Operation and Control

The proposed community microgrid will operate in grid-connected, islanded, and partly islanded modes. The advanced controller used in this microgrid and the DERs proposed in this project will support the microgrid to transfer seamlessly between the different modes. The three stakeholders could be running as a community microgrid during a power outage. Energy could be exchanged among the three stakeholders. The generation resources in different stakeholder locations would be optimally dispatched and controlled to provide economic benefits and better service to current customers toward resilient and zero-emission communities. The proposed technical solution would improve current stakeholders' and customers' power supply reliability and resiliency.

Under normal conditions, the Winch Park Municipal Resiliency System (WPMRS) would be operated in a grid-connected mode to maximize the economic benefits for the customers or stakeholders. The WPMRS master controller will optimize energy purchases from the utility grid and generation and storage from the local DERs to minimize the total energy cost while maintaining the reliability and stability of the microgrid.

In emergency conditions such as utility grid outages, the proposed addition of solar and storage will allow the community microgrid to disconnect from the surrounding Eversource electrical distribution and transmission infrastructure and supply its power for hours to days, based on the level of load curtailment. Within each stakeholder's location, the solar generation and battery would optimally be dispatched to serve the critical loads first. With the proposed WPMRS, the operation hours of the existing backup diesel generators could be significantly reduced, and reduced GHG emissions could result.

Additional loads would need to be curtailed during major storms or other extreme events when the electric utility service is unavailable for long periods. Suppose no load is curtailed in a resiliency-focused solution. In that case, the sites could be served by backup generators, solar, and batteries for around 5-7 days with sunshine or around 3-5 days for each of the stakeholder locations, respectively, when solar generation is not available. However, if non-critical loads are curtailed and the facilities focus on serving their critical resources such as lighting, police, fire, and alarm systems, administrative offices (for emergency coordination), and emergency shelters, the WPMRS could serve these critical facilities for weeks depending on the available fuel supply. This assumes a critical load at 406 kW of 975kW peak load (Table 10) for an extended period of days to weeks, depending on the availability of diesel delivery service for the backup units. In the case of no available fuel for backup generators, the proposed solar-battery system could support the critical loads for 6 hours to 3 days for each of the stakeholder locations, depending on its load and the available solar PV installation potential (around 6 hours for PS, 36 hours for FS2, and 72 hours for FHS based on clean energy supply). If connected and running as a community microgrid, the clean energy could supply the critical loads for up to 48 hours

Stakeholders, like PS, can be configured to be disconnected from the rest of the community microgrid and run independently as a building microgrid to reduce the complexity of the energy exchange and operation for reliability purposes. The connected community microgrid is recommended for an extra layer of resiliency and economic merits. During the detail design or operation stage, the interconnection and configuration would need to be further verified with PS.



4.1.4 Interconnection with Utility Grid

The microgrid will be interconnected to the Eversource distribution grid at the interconnection point, labeled as PCC in **Figure 1**. In the proposed configuration, each of the stakeholder locations can be operated in islanded mode independently. Any interconnection application between 1-5 MW has the potential for a transmission review by the Independent System Operator, New England (ISO-NE), which may cause a longer interconnection process and approval.

The local microgrid distribution grid and controls will be based on a combined solar-battery system with switches, reclosers, circuit breakers, and relays set up to prevent fault currents or back feeding from damaging the grid infrastructure or sensitive loads. Relays can be connected through a wired or wireless system to allow for fault isolation and automated reclosing as well as to provide grid data to the Supervisory Control and Data Acquisition (SCADA) system or microgrid operator. Wired and wireless systems can back up and compensate each other to improve the overall resiliency in different extreme conditions. Additionally, the frequency and harmonics of the grid will be monitored at critical points using phasor measurement units (PMUs) to maintain grid balance during islanding and resynchronization events.

Integrating DERs and novel topologies embedded in microgrids also pose great challenges to traditional protection schemes. Such challenges are mainly derived from the fact that the protection devices deployed in the present distribution systems are coordinated based on unidirectional downstream power flows, where the utility grid provides the fault current and protection devices are coordinated along the radial feeders to isolate faults. A hierarchical protection configuration strategy is proposed for the WPMRS protection that mainly contains four-level protection: load way, feeder way, microgrid way, and microgrid cluster level¹⁶.

- Load-way protection: Digital relay with adaptive relay setting, responding to lower fault current in islanded mode, operates only in load-way faults.
- Feeder-way protection: Feeder-way protection has similar functions as load-way protection. The occurrence possibility of this backup is very low. Directional over-current relays are considered to be super high accuracy and reliability. Digital relay with adaptive relay setting. Operates primary and backup permissive overreach transfer trip (POTT) schemes in feeder faults. Backup protection for load-way protection.
- Microgrid-level protection:
 - In grid-connected mode: Unintentional islanded operation due to external fault or disturbance based on the signal from the master controller (MC), backup protection for the entire microgrid, and intentional islanded operation based on the islanding command from the MC.
 - In islanded mode: Resynchronization initiated by a command from the MC.
- Microgrid cluster protection: Operates to isolate the faulted microgrid only when the load-way or feeder-way protections have failed within the cluster.

Each level is equipped with protection devices and the four levels are coordinated. The load-shedding and other control schemes can also be implemented on the load-way protection level, based on the under-

¹⁶ L Che, ME Khodayar, M Shahidehpour, "Adaptive Protection System for Microgrids: Protection practices of a functional microgrid system," IEEE Electrification magazine, 2014



/over-voltage and under-/over-frequency functions of these relays. The performance modes of microgrid protection are summarized as follows.

- Detection and isolation the faults both inside and outside of the microgrid
- Detection and isolation the faults inside the microgrid in both grid-connected and islanded mode
- Detection and immediately isolation the faults of the loads and DERs
- Prime protection and backup protection for protection device malfunction
- Compromise between selectivity and speed, depending on the level and seriousness of the faults. Those faults could cause serious damages or consequences are equipped and monitored by protection devices and action with high priority and fast response speed.

4.2 Load Characterization

4.2.1 Summary of the WPMRS Loads

The hourly granular electricity loads are available for FHS and the PS. Only historical monthly usage and billing data are available for FS2. The average, peak and critical loads of these stakeholders were collected through either a request for information (RFI) or a resiliency survey, and are summarized in **Table 10**. The optimal solution is calculated based on the 8,760-hour load shape in this section.

Table 10. WPMRS Average, Peak, and Critical Electrical Loads

Stakeholder	Critical Buildings/Loads	Average Load (kW)	Peak Load (kW)	Critical Load (kW)
FHS	Elevator, security lighting, fire panel, and the front lobby area including lighting, plugs, cooling and ventilation for that space.	247	813	244
PS	All loads, whole facility should be treated as critical load	73	134	134
FS2	All loads, whole facility should be treated as critical load	15	28	28
Total		335	975	406

4.2.2 Hourly Load Shapes of Each Stakeholder

Framingham High School

The estimated annual hourly electric load shape and peak day load shape of FHS are shown in **Figure 18** and **Figure 19**, respectively. The average electricity load is 243 kW. Peak electricity load is around 814 kW in the summer, coinciding with the air conditioner usage. The load profile on a peak load day is shown in **Figure 19**. On average, FHS pays \$0.22/kWh for electricity usage, including the energy cost from the power supplier and the delivery charge from the utility. The monthly thermal load and cost are shown in **Figure 7**. FHS’s annual electricity and heating loads are 2,131,080 kWh and 140,184 therms¹⁷, respectively. The monthly energy usage, cost, and demand for the year 2019 are shown in **Table 11** and **Figure 20**.

¹⁷ MassCEC CLEAR Program Energy Data (3-3-22).xlsx



Figure 18. FHS Hourly Electricity Load Profile (2019)




Figure 19. FHS Electricity Load Profile on a Peak Day





Table 11. Energy Usage and Cost for FHS in Year 2019

Month	2019					
	Electricity Usage (kWh)	Electricity Cost (\$)	Gas Usage (Therm)	Gas Cost (\$)	Averaged Electricity (\$/kWh)	Averaged Gas Cost (\$/Therm)
Jan	185,760	66,376	24,717	22,232	0.36	0.90
Feb	207,720	37,196	30,578	27,369	0.18	0.90
Mar	184,760	34,758	23,255	20,782	0.19	0.89
Apr	170,560	33,121	13,017	11,685	0.19	0.90
May	172,040	33,467	5,326	3,811	0.19	0.72



Jun	180,480	39,722	937	612	0.22	0.65
Jul	136,960	33,829	919	637	0.25	0.69
Aug	146,320	37,114	675	435	0.25	0.64
Sep	186,440	44,844	1234	647	0.24	0.52
Oct	181,440	40,769	3,326	1,446	0.22	0.43
Nov	195,920	37,455	14,410	12,050	0.19	0.84
Dec	182,680	33,914	21,790	22,370	0.19	1.03

Figure 20. FHS Monthly Electricity Demand



Fire Station #2

The estimated hourly load shape for FS2 is shown in **Figure 21**, with an average electricity load demand of 15.2 kW. The estimated hourly load shape in peak load data is shown in **Figure 22**. The annual electricity usage is 134,000 kWh and the cost is \$23,763, respectively, based on the available customer electricity data in 2021.



Figure 21. FS2 Estimated Hourly Electricity Load Profile




Figure 22. FS2 Estimated Hourly Electricity Load Profile in Peak Load Day




Table 12. Energy Usage and Cost for FS2 (Year 2021)


Month	2021					
	Electricity Usage (kWh)	Electricity Cost (\$)	Gas Usage (Therm)	Gas Cost (\$)	Averaged Electricity (\$/kWh)	Averaged Gas Cost (\$/Therm)
Jan	12,000	1,935	1,255	1,499	0.16	1.19
Feb	13,600	2,092	1,668	1,984	0.15	1.19



Mar	11,600	1,828	1,247	1,489	0.16	1.19
Apr	11,200	1,719	753	907	0.15	1.20
May	10,000	1,583	390	387	0.16	0.99
Jun	10,000	1,866	165	154	0.19	0.93
Jul	10,800	2,424	83	88	0.22	1.06
Aug	11,600	2,338	60	72	0.20	1.20
Sep	12,400	2,649	75	86	0.21	1.15
Oct	9,200	1,808	228	231	0.20	1.01
Nov	10,400	1,735	778	941	0.17	1.21
Dec	11,200	1,787	1,054	1,436	0.16	1.36

A Street Pumping Station

Figure 23. PS Annual Hourly Load Profile (2019)



A Street Pumping Station

Figure 23, with a peak load of 134 kW and average demand of 71 kW. The annual electricity usage is estimated at 623,272 kWh. The hourly load profile on a peak load day is shown in **Figure 24**. PS’s monthly energy usage, cost and demand for the year 2019 are shown in **Table 13**.



Figure 24. PS Hourly Load Profile in Peak Load Day




Table 13. Energy Usage and Cost for PS (Year 2019)

Month	2019					
	Electricity Usage (kWh)	Electricity Cost (\$)	Gas Usage (Therm)	Gas Cost (\$)	Averaged Electricity (\$/kWh)	Averaged Gas Cost (\$/Therm)
Jan	57,400	19,105	1,427	1,317	0.33	0.92
Feb	59,416	9,981	2,638	2,391	0.17	0.91
Mar	51,928	8,449	1,653	1,509	0.16	0.91
Apr	49,760	8,167	1,033	958	0.16	0.93
May	55,936	9,198	550	421	0.16	0.77
Jun	44,472	8,078	272	194	0.18	0.71
Jul	52,440	10,676	150	115	0.20	0.77
Aug	54,200	9,721	129	100	0.18	0.78
Sep	49,832	9,077	422	220	0.18	0.52
Oct	44,520	7,772	1,258	541	0.17	0.43
Nov	51,544	8,224	3,067	2,579	0.16	0.84
Dec	51,824	8,976	2,866	2,966	0.17	1.03



4.2.3 Load Aggregation for WPMRS Simulation

The hourly load profile for all stakeholders is shown in **Figure 25**. The aggregated hourly load profile based on the current load data for WPMRS is shown in **Figure 26**. For the analysis of WPMRS, the aggregated peak load considered was 912 kW and the annual average load was 335 kW.

Figure 25. Averaged Hourly Electrical Load Profile in WPMRS





Figure 26. Aggregated Averaged Hourly Electrical Load Profile in WPMRS



4.3 Distributed Energy Resources Characterization

4.3.1 Description of Microgrid DERs

It is assumed that the stakeholder would pay a fixed electricity rate of \$0.09593/kWh based on the contract through WPMRS. Transmission and distribution charges are paid to Eversource for electric delivery, and the rates and charges are different based on the service level of the accounts. The demand charge is different for different seasons; i.e., summer peak season and winter off-peak season. The detailed demand charges, energy costs, and gas prices used in the modeling are summarized in **Table 14** for the simulation. The gas price is included here for the total energy cost calculation.

Table 14. Price Parameter Used in Simulation

Month	Electricity Energy Price (\$/kWh) ¹⁸	Demand Charge (\$/kW-Month)	Gas Price (\$/Therm)
Jan	0.13947	20.4	0.9
Feb	0.13972	20.4	0.9
Mar	0.12887	20.4	0.9
Apr	0.12633	20.4	0.9
May	0.11847	20.4	0.9
Jun	0.1116	29.62	0.9
Jul	0.1116	29.62	0.9
Aug	0.1116	29.62	0.9
Sep	0.1116	29.62	0.9
Oct	0.13947	20.4	0.9
Nov	0.13972	20.4	0.9
Dec	0.12887	20.4	0.9

Two scenarios were simulated with the aggregated hourly load profile and costs in this section. The preliminary cost-benefit analysis is summarized in **Table 15**. In **Table 15**, the incentives for solar and battery storage installation, such as federal tax credits, smart solar, energy efficiency rebate/incentive programs, etc., are considered in the next section (Task 4 Financial Solutions). The Resiliency scenario was selected and presented as the primary solution in this report, based on stakeholder feedback.

¹⁸ Including the current contracted energy supply rate \$0.09593/kWh between Framingham and energy supplier, the kWh/kW charge in Eversource delivery service (Distribution, Transition, Revenue Decoupling, Distributed Solar Charge, Renewable Energy, and Energy Efficiency)



Table 15. WPMRS Preliminary Configuration and Cost Analysis Summary

	Base	Resiliency	Economic
Technical Data			
Solar Capacity (kW)	-	1,164	1,164
Battery Capacity (kW/kWh)	-	610/2440	290/660
CO ₂ Emission (metric ton)	1,454	1,151	1,153
CO ₂ Reduction (metric ton)	-	303	301
Solar Generation (kWh)	0	1,509,136	1,509,136
Battery Charged by Solar (%)	0%	100%	100%
Current Annual Load (kWh)	2,888,352		
Load Offset by Solar (%)	0%	52%	52%
Preliminary Economic Data			
Annual Electric Costs (\$)	613,753	284,043	335,641
Annual Fuel Costs (\$)	146,661	146,661	146,661
Annual Energy Cost (\$)	760,414	430,704	482,302
Annual Energy Cost Saving (\$)	-	329,710	278,112
Investment Cost (Battery) (\$)	-	1,525,000	412,500
Investment Cost (Solar) (\$)	-	3,783,000	3,783,000
Infrastructure Cost (\$)	-	70,000	70,000
Total Investment Cost (\$)	-	5,378,000	4,265,500
Project Administration Cost (\$)	-	1,344,500	1,066,375
Total Project Cost (\$)	-	6,722,500	5,331,875

The preliminary cost analysis for each stakeholder is presented in **Table 16** through **Table 18**. The capacity value of battery storage has a big impact on the payback year since a battery energy storage system (BESS) is mainly for reliability improvement benefits. BESS is able to reduce the demand charge cost but did not generate significant revenue, based on the demand charge assumption (averaged at \$7.83/kW-month).



Table 16. WPMRS Preliminary Cost Analysis (FHS)

FHS	Base	Resiliency	Economic
Technical Data			
Solar Capacity (kW)	-	1,060	1,060
Battery Capacity (kW/kWh)	-	500/2000	250/500
CHP (kW)	-	0	0
CO ₂ Emission (metric ton)	1,177	902	905
CO ₂ Reduction (metric ton)	-	275	272
Solar Generation (kWh)		1,374,299	1,374,299
Battery Charged by Solar (%)	0%	100%	100%
Current Annual Load (kWh)		2,131,080	
Load Offset by Solar (%)	0%	64%	64%
Preliminary Economic Data			
Annual Electric Costs (\$)	472,565	179,013	227,261
Annual Fuel Costs (\$)	124,076	124,076	124,076
Annual Energy Cost (\$)	596,641	303,089	351,337
Annual Energy Cost Saving (\$)	-	293,552	245,304
Investment Cost (Battery) (\$)	-	1,250,000	312,500
Investment Cost (Solar) (\$)	-	3,445,000	3,445,000
Infrastructure Cost (\$)		50,000	50,000
Total Investment Cost (\$)	-	4,745,000	3,807,500
Project Administration Cost (\$)	-	1,186,250	951,875
Total Project Cost (\$)	-	5,931,250	4,759,375



Table 17. WPMRS Preliminary Cost Analysis (FS2)

FS2	Base	Resiliency	Economic
Technical Data			
Solar Capacity (kW)	-	52.8	52.8
Battery Capacity (kW/kWh)	-	50/200	15/60
CO ₂ Emission (metric ton)	68.0	51.7	51.8
CO ₂ Reduction (metric ton)	-	16.3	16.2
Solar Generation (kWh)	0.0	68,455.7	68,455.7
Battery Charged by Solar (%)	0%	94%	100%
Current Annual Load (kWh)	134,000		
Load Offset by Solar (%)	0%	60%	60%
Preliminary Economic Data			
Annual Electric Costs (\$)	23,763	11,217	12,041
Annual Fuel Costs (\$)	9,274	9,274	9,274
Annual Energy Cost (\$)	33,037	20,491	21,315
Annual Energy Cost Saving (\$)	-	12,546	11,722
Investment Cost (Battery) (\$)	-	125,000	37,500
Investment Cost (Solar) (\$)	-	171,600	171,600
Infrastructure Cost (\$)	-	10,000	10,000
Total Investment Cost (\$)	-	306,600	219,100
Project Administration Cost (\$)	-	76,650	54,775
Total Project Cost (\$)	-	383,250	273,875



Table 18. WPMRS Preliminary Cost Analysis (PS)

PS	Base	Resiliency	Economic
Technical Data			
Solar Capacity (kW)	-	51	51
Battery Capacity (kW/kWh)	-	60/240	25/100
CO ₂ Emission (metric ton)	209	197	196
CO ₂ Reduction (metric ton)	-	12	13
Solar Generation (kWh)	0.0	66,381.2	66,381.2
Battery Charged by Solar (%)		76%	100%
Current Annual Load (kWh)	623,272		
Load Offset by Solar (%)	0%	10%	10%
Preliminary Economic Data			
Annual Electric Costs (\$)	117,425	93,812	96,339
Annual Fuel Costs (\$)	13,311	13,311	13,311
Annual Energy Cost (\$)	130,736	107,123	109,650
Annual Energy Cost Saving (\$)	-	23,613	21,086
Investment Cost (Battery) (\$)	-	150,000	62,500
Investment Cost (Solar) (\$)	-	166,400	166,400
Infrastructure Cost (\$)		10,000	10,000
Total Investment Cost (\$)	-	326,400	238,900
Project Administration Cost (\$)	-	81,600	59,725
Total Project Cost (\$)	-	408,000	298,625

The primary generation source for the proposed community microgrid (WPMRS) capacity would include the roof-top solar and solar canopy in the parking lot, with a total capacity of up to 1,164 kW; and battery storage, with a total capacity of up to 610 kW/2,440 kWh. Battery storage would be charged by solar generation during daytime and discharged for supplying load during the night or charged during off-peak periods and discharged during high-demand cost periods under a time of use or real-time pricing rate.

Locations and space available for solar are shown in **Figure 27** through **Figure 29**, matching the totals in **Table 9**. In this report, all the potential space for solar are proposed for solar installation to maximize the benefits considering the onsite load level. Adequate space for battery installation was identified during the site visits conducted during Task 2. Small size of battery like the one proposed for FS2 could be installed indoor if space is available with required temperature control and fire protection. Larger batteries (over 500-1,000 kWh) can be located outside in NEMA-rated enclosures with integrated temperature control and fire protection.



Figure 27. FHS Solar PV Layout (1,060 kW)



Figure 28. FS Solar PV Layout (52.8 kW)




Figure 29. PS Solar PV Layout (51.2 kW)



4.3.2 Ability of DERs to Serve Load and Provide Resilience

During normal operating conditions, i.e., grid-connected mode, the microgrid generation resources would operate in parallel to the grid. The load would be continuously met through an approximately 52% annual offset of local distributed generation with the remaining electricity purchased from the utility.

DER assets will be installed considering flood and storm risks and rated accordingly. Modern solar panel rooftop racking is highly resistant to weather conditions and can be rated for 120 mph winds and greater. Switchgear and other electrical infrastructure will be raised above flood levels to prevent equipment malfunction due to climate change. Traditional generation and battery equipment will be installed indoors or in weather-rated containers.

The WPMRS controller would coordinate and dispatch the charge activity of battery storage and dispatch the energy generated by DERs located at different locations.

4.3.3 Fuel Sources for Fossil Fuel DERs

If the diesel supply is disrupted, the microgrid critical loads will continue to be electrically served by solar and storage for a period of 6-72 hours, long hour capacity for FHS with large solar PV installation, short hour for FS2 and PS due to limited space for solar PV with solar generation recharging the batteries during the day for continuous operation. With reconfiguration and authorization by each of the DER owners, the connected stakeholders can share their generation resources among each other in community microgrid mode for optimizing the usage of the existing backup generation resources to support the critical loads, which could serve the critical load for up to 48 hours before running the backup diesel generators.

4.3.4 DER Capabilities

The microgrid controller enables the DERs to respond quickly to energy needs, change ramp direction on demand, sustain up/down ramping for extended periods, start/stop multiple times a day, respond for defined periods of time on request, start with a short notice from zero or low-electricity operating level, and forecast operating capability through the economic dispatch and real-time management of DERs such as solar and battery storage. This includes maintaining voltage and frequency in grid-following mode and



utilizing battery and solar inverters to ride through islanding and resynchronization events. This will be done according to IEEE 2030.7 standards, following the IEEE 2030.8 guidelines.

4.4 Electrical and Thermal Infrastructure Characterization

Whenever possible, the existing overhead/underground distribution cables will be used to connect the different microgrid stakeholders. The overhead distribution cables connecting the three sites could be changed to underground cables to increase resiliency further.

4.4.1 Simplified Electrical and Thermal Infrastructure Diagram

The conceptual simplified infrastructure diagram is presented in **Figure 1**. The connected substation and feeder for each stakeholder are summarized in **Table 19**. The three stakeholders are fed by the same feeders.

Table 19. Summary of Distribution System (Substation, Feeder and Capacity)¹⁹

Stakeholder	Study Area	Substation	Voltage (kV)	Feeder	Capacity
FHS	Winch Park	STE-433	13.8	433-H4	4 MW left ²⁰
PS			13.8	433-H4	
FS2			13.8	433-H4	

4.4.2 WPMRS Meter Consolidation

The physical interconnection of the microgrid to the Eversource distribution system involves the physical consolidation of the site’s meters into one master meter.

Physically consolidating all the sites to a single meter allows for a true microgrid, where solar generation from one building can be shared with other buildings and with each of the stakeholders. It can also lower monthly fees due to reduced meter charges and energy/demand prices at a higher service level. These benefits may come with the significant capital, time, and effort expenditure required for the civil engineering and construction costs. Wherever possible, underground submersible switchgear and vaults will be used to improve distribution resilience and minimize the visual impact on the community. Depending on the ability to use the existing distribution equipment and conduit (of which limited information is available as of the publication date of this report), the sophistication of the switchgear, and communications to support the relays and circuit breakers for this system could cost between \$500,000 and \$3,000,000²¹.

FHS, FS2 and PS belong to the City and were with the same third-party power supplier (Public Power & Utility). As confirmed by Eversource, it may be challenging and difficult to aggregate the loads in different locations and electricity tariffs²².

¹⁹ <https://www.eversource.com/content/nh/business/about/doing-business-with-us/builders-contractors/interconnections/massachusetts/hosting-capacity-map>

²⁰ Framingham Request for Information 1.13.2021 – Confidential stamp.pdf

²¹ Rough estimation based on the discussion with Eversource Energy. Meter consolidation is possible for multiple meters belonged the same customer. Big challenges for multiple meters belonged to different customers under current regulation.

²² FHS Tariff: RATE B7-NEMA LG GENERAL TOU, FS: Rate B2-LARGE GENERAL-SECONDARY, PS Tariff: RATE B7-NEMA LG GENERAL TOU



4.5 Microgrid and Building Controls Characterization

The WPMRS will demonstrate several technological advancements and breakthroughs that will help the stakeholders achieve their energy goals. The critical breakthrough is the proposed development methodology that synchronously considers both system planning (LoadSEER) and simulated operation (IDROP and OPAL-RT), resulting in maximum efficiency and responsiveness in developing a microgrid configuration with an optimal mix of DERs, cyber-secure communication, real-time controllability and visibility, and islanding capability. The proposed methodology supports a high penetration of intermittent renewable energy resources by introducing a controllable and flexible load at the microgrid level.

4.5.1 Microgrid Controls Diagram

Most existing controller solutions use proprietary data architectures that limit interoperability with other platforms and systems, decreasing their applicability and replicability. The Microgrid Controller Technology Stack (MCTS) shown in **Figure 30** does not use proprietary architectures, replacing the current technology with utility-approved, cyber-secure components already deployed in utility-scale applications but leveraged to account for, and adjust to, real-world data inputs, which produces the optimal DER mix. LoadSEER is used in PG&E’s load forecasting and planning, IDROP is used in SCE’s utility-scale DER fleet management, PXISE is used in SDG&E’s Borrego Springs Microgrid, and PI System²³ is used as the vast majority of major IOUs’ historian and SCADA databases. MCTS will advance these current technologies by showing how they can address a current issue in microgrid implementation.

Willdan Microgrid Control Technology Stacks (MCTS) includes three components: Planning, Operation (Implementation Management and Assets & Services Management), as shown below:

PLANNING: In this phase, using the geospatial platform, LoadSEER will site and size the distributed energy resources (DERs) to reflect the local parameters (weather and distribution network information) microgrid adopters Economic, Environmental, and Resilience (EER) goals (Owner and operators, Off-takers), while considering the Eversource distribution network constraints and limitations through iterative simulation of the proposed solution. We test the operation of the proposed system in the lab environment using the simulation software (IDROP in this case) to guarantee the EER capabilities of the proposed solution (Operation Check) and real-world operation of the system in the simulated utility environment using hardware-in-the-loop technology to assure the safe, reliable operation of our proposed microgrid (Network Check). This will reduce the permitting process significantly.

Implementation Management: Using the EER goals and Distribution Network compliant solution generated in the previous phase, our team will work with the stakeholders to procure the required permits, technologies, and services and construct and commission the proposed microgrid according to the layout generated in the previous phase, and pass the system to the owner and operator.

Assets & Services Management: This part of our solution is about the operation of the proposed microgrid in the real world to serve the microgrid adopter and owner, and operator and secure the EER and distribution network-compliant performance (Measurement & Verification) using three technology pillars:


- Energy Resources Management (IDROP in this Case)

²³ PI System is developed by OSISoft, LLC which belonged to Aveva Group



- Distribution Network Stability Security Check (PXISE in this Case)
- Data Collection, Integration, Management, and Analytic Platform (OSI PI in this case)

Figure 30. WPMRS Master Controller Technology Stack (MCTS)



In microgrids, the primary control offers a localized control in real-time, designed to realize load sharing among parallel-connected DERs without needing communication channels between DERs.

The secondary control is disabled in grid-connected mode since the voltage is maintained by the utility grid. In islanded mode, the secondary control would eliminate voltage deviations without adjusting the dispatch of parallel DERs. Once a voltage deviation is detected, the secondary control would generate a voltage compensation signal to uplift the droop curve and restore the rated voltage without changing the DER dispatch.



The economic and optimal operation of microgrids necessitates an upper-level tertiary control. The master controller is the most important microgrid element, mainly responsible for tertiary control for optimal operation and dispatch, and can execute secondary control during emergencies like islanding or resynchronizing. The master controller obtains data from the generation and load entities through supervisory control and data acquisition (SCADA).

Willdan takes utility-approved applications (LoadSEER, IDROP, OPAL-RT, PXiSE, and OSIsoft PI system) and combines them into two technology stacks—planning and operations—to allow a continuous feedback loop that maximizes efficiency and responsiveness to real-world conditions in an optimized microgrid configuration.

This configuration will reliably serve stakeholders while satisfying Eversource’s requirements by using proven technologies in planning technology stack to analyze and optimally size and site DERs in the WPMRS. This innovation will address a significant barrier to microgrid implementation, that is, the disconnection between planning and real-time operation, by analyzing a constant stream of simulated and actual data that can be used to plan and course-correct the operation of the microgrid.

The MCTS enables the WPMRS to respond quickly to energy needs, change ramp direction on demand, sustain up/down ramping for extended periods, start/stop multiple times a day, and provide optimal dispatch and forecast operating capability through the economic dispatch and real-time management of DERs such as solar and battery storage, and the dispatchable load demands.

The MCTS shown in **Figure 30** enables the integration and interoperability of different systems and components—including real-time communication with the electric grid and ISO New England energy market using a standard interface and cyber-secure communications protocol. The WPMRS will follow the IEEE 2030.8 guidelines for simplifying communication and integration between different equipment and device. The microgrid controller’s open architecture allows the integration of different system components. It supports interoperability through cyber-secure, standard interfaces, and communications, increasing the project’s replicability and scalability, which will help adopt new information, power, and energy technologies in the WPMRS. The MCTS shown in **Figure 30** unlocks the full economic value of DERs by factoring in real-time grid conditions (power flow, network constraints) and stakeholder requirements (peak-shaving, power quality, energy costs). Its platform of capabilities can manage additional public works services, increasing the commercial viability of the controller.

MCTS includes a series of software packages that could be deployed either onsite or hosted in the cloud. If hosted onsite, the MCTS server could be installed in any indoor environment with an uninterruptible power supply (UPS), such as a battery container or an existing electrical room. One standard 42U server rack (H: 78 inches, W: 23.6 inches, D: 40 inches) would accommodate all the necessary servers, power supply, and display equipment, with spare space for future upgrades.

4.5.2 Microgrid Services and Benefits

WPMRS would provide extra layer resiliency benefit in addition to the existing backup generators, 6-72 hours of backup and islanding capacity using proposed clean solution vary by sites, long hours for FHS with large solar PV, short time for FS2 and PS due to limited space for solar installation. A community microgrid could enable a critical facility like FS5 and PS to run on a clean energy supply for an extended time by allowing the energy exchange between the three sites. CSCRS would also provide benefits and values including, but not limited to, microgrid services in grid-connected (ancillary services, power quality



services, quality of services, intermittency alleviation, reliability improvement to sensitive loads such as security system) and islanded mode (black-start and resiliency), non-energy related and societal benefits such as workforce training, emerging technologies evaluation testbeds, and other smart grid services.

WPMRS will help stakeholders evaluate the actual benefits of the project and may inform future state policy considerations. OSIsoft’s PI Historian database will be used to store data; perform event tracking of tests, outages, and equipment usage; monitor operations; analyze performance; and evaluate costs/benefits in real time or over a period of months or years.

WPMRS will demonstrate how using advanced data analytics in a community microgrid contributes to Integrated Resource Planning, specifically to defer generation, transmission, and distribution upgrade costs, which are passed on to ratepayers as cost reductions. WPMRS also will demonstrate how integrated DER controls can respond to load-following and ramping needs at the local grid and system levels. For the project stakeholders, this will lower bills, provide more reliable energy services, and lead to a cleaner environment. The proposed project specifically will benefit stakeholders with greater reliability, lower costs, and increased safety, as described below.

4.5.2.1 Improved Reliability

- a. WPMRS is designed to incorporate high DER penetration. Under this design, even if a few DERs fail, the rest of the DERs within the system will remain operational, ensuring microgrid stability and reliability.
- b. The WPMRS MCTS will provide ISO-NE and Eversource with DER visibility, supporting daily operations and providing their customers with higher reliability.
- c. The proposed control package has islanding capability, so it can continue to function in the event of an electric grid disruption, increasing grid stability and power quality.
- d. The WPMRS uses renewable sources of generation, decreasing dependency on natural-gas-powered peak plants, which are subject to supply disruptions.

4.5.2.2 Potential Energy and Cost Savings

- a. WPMRS’s inclusion of energy efficiency and renewable generation lowers power procurement, generation, utility, and microgrid stakeholder costs, and can defer peak power plant, transmission, and distribution infrastructure upgrade costs. On a broader scale, lowering these costs could help result in future decreases in Eversource’s ratepayer costs.
- b. The WPMRS MCTS will provide efficient real-time operational schemes that allow microgrid operators to monitor and manage the microgrid assets more economically and efficiently.
- c. The WPMRS will consider Eversource’s interconnection requirements, reducing overall engineering efforts for both the utility and the community microgrid developer.
- d. The WPMRS MCTS provides the utility with visibility, which enables more efficient operation (e.g., grid-level DER dispatch) and grid services (e.g., ramp up/down, support more storage, less intermittency and generation curtailment).
- e. Optimally dispatching load demand with the battery storage dispatch and solar PV generation across the three locations would result in demand charge savings, energy savings and maximized utilization of solar generation and load demand response.

4.5.2.3 Safety

- a. This proposed project will lower the running hours of backup natural gas generators and reduce natural gas use, which minimizes stress on the current aging natural gas infrastructure.



- b. The WPMRS lowers the base load and provides peak shaving through the MCTS.
- c. The WPMRS provides an alternate energy source, decreasing the impact of potential incidents, such as gas leaks.
- d. The proposed system will provide power to WPMRS-designated emergency shelters during prolonged grid disruptions caused by natural disasters (e.g., winter storms, fires, heat waves, and floods).
- e. The visibility provided by the microgrid controller increases safety for maintenance workers investigating system faults by showing the shortest path to correct the fault.
- f. Locally generated power through DERs reduces the level of power flow necessary on campus distribution infrastructure, decreasing electrocution risks to electrical workers and for public safety issues such as exploding transformers.

4.5.3 Load Management and Resilience

A community microgrid has the capability of supplying power to critical facilities from battery storage and local DERs to improve the energy resilience of critical facilities. In cases of extreme weather events, if one building microgrid fails due to less generation, the loads can be served by the generation resources located at another stakeholder’s territory. With the proposed solar PV and battery storage in each of the sites, the energy consumption and demand could be managed effectively. More reliable and resilient power service could be achieved by dispatching DER assets and load in all stakeholder locations.

4.6 Information Technology (IT)/Telecommunications Infrastructure Characterization

Any modern utility or system operator relies heavily on their communication infrastructure to monitor and control their grid assets. For a microgrid master controller and microgrid operators, this architecture enables real-time control, the rapid digestion of critical grid information, and historical data for analysis and reporting. As part of a feasible microgrid, the assessment and upgrade of the equipment and protocols used in the microgrid area will be performed.

4.6.1 IT/Telecommunications Layout Diagram

The planned development area is expected to have communication systems varying from wi-fi to dedicated fiber optics for critical information systems. Building management systems rely on BACnet, Modbus or Lonworks (ISO/IEC 14908) over serial or Ethernet. Controls for chillers, boilers, WPMRS’s existing distributed heating system, thermostats, air-handling units, lighting, and others use various wired or wireless networks and protocols, depending on when they were purchased or upgraded. Often, vendor-specific proprietary networks are deployed as technology progresses with little regard for data consolidation. Especially in a campus environment, networks are set up for research and operations with IT departments, often struggling to maintain services and prevent attacks rather than consolidate various networks and devices.


With the development of WPMRS, whenever possible, existing communications and control infrastructure will be leveraged to avoid re-training operators and excess capital expenditures. This is possible due to the framework of OSISoft’s PI Historian, which allows for the integration of every major vendor’s proprietary protocol and every standard protocol and has been tested and integrated with billions of devices. This includes building and lighting controls, central plant operations, generators, and any other existing equipment that microgrid owners or campus personnel want to monitor from one



easy-to-search, easy-to-access system. The OSIsoft PI system can equip the microgrid controller with the supervisory control and data acquisition (SCADA) system for monitoring and regulating the microgrid operation, synchronizing and integrating the data transmitted to and from the microgrid controller via diverse communication protocols. The OSIsoft PI system also provides an intuitive web-client visualization tool that offers access to real-time information in a fast, easy, and secure manner so that a microgrid operator can gain sufficient insights into microgrid conditions based on data-driven analyses.

The high-level communication system architecture for WPMRS is shown in **Figure 31**. The major equipment installed on the stakeholder’s site would be the proposed solar PV, either roof solar or solar canopy depending on the site, along with combined battery storage. A local controller hosted in an onsite server or in the cloud would be deployed to monitor, communicate with and control the local DERs and loads. Each stakeholder will operate within its own internal network, with wireless cellular backhauls connecting the systems with a cyber-secure cloud database. New grid controls and any upgraded building controls, along with master controller inputs and control points, will also be connected. The microgrid owner/operator(s) will have full control of and access to the microgrid systems. This could be the WPMRS operators running their own system, Eversource operating some of the system, or a contracted Operations and Maintenance (O&M) firm running the entire system.

Figure 31. WPMRS Proposed Communications and Control Diagram



Public access to the high-level generation and operation of the system can be granted through a simplified online portal or on-campus display to allow for education and community engagement.



4.6.2 IT/Telecommunications Operation

The WPMRS would be connected efficiently and productively, with modern communication architectures and equipment, enabling a master controller to optimize the microgrid control and giving operators the tools that they need to maximize the benefits of the microgrid to the stakeholders. Exact upgrades or additions to existing communications infrastructure will need to be determined during a detailed design phase.

The grid operations equipment, i.e., circuit breakers, relays, reclosers and other switchgear, are vital to the control of the WPMRS. While some distributed switchgear can utilize wireless infrastructure, with data being fed through utility substations instead of through a cloud network, the control equipment is more vital to the safe operation of the microgrid and would ideally use a fiber-optic backbone between the WPMRS master controller substations and grid switches. The substation relays will be upgraded or designed to communicate using the DNP3 protocol over TCP/IP, the de facto standard for modern utility communications, which will be used to monitor and control the proposed DER as well. Once collected locally, the data will be fed into an upgraded or added SCADA system to allow operators to access, visualize, and control all the microgrid assets from a central control center located on or off the campus.

If an O&M firm is contracted, they can be responsible for the communications infrastructure and associated electrical and controls equipment that is critical to the operation of the microgrid. If the WPMRS decides to hire staff and operate the system itself, the existing IT department will be trained on the maintenance and operation of the communications system.

The microgrid status and operation data will be shared with Eversource at the microgrid stakeholder's discretion. This could be limited data provided through an online Application Programming Interface (API) or portal, which would be subject to internet availability and its associated reliability. However, the use of the planned controller allows for a dedicated connection of real-time operations and control data using the OSIsoft PI database. Additionally, Eversource could use its own backhaul network to bring microgrid operations data back to its emergency operations center if it plans to leverage the microgrids for a black-start capability to re-energize its lines. In the case of operating or controlling the DER asset within the proposed microgrid, Eversource would need to send the request to the microgrid controller through which the control commands are sent to the target units. The proposed microgrid would provide Eversource or other regulation departments with an interface that could oversee or monitor the microgrid running status for grid reliability and stability purposes.

4.7 Conclusion

In the proposed WPMRS, the generation resources in different stakeholder locations would be optimally dispatched, coordinated and controlled to provide economic benefit and better resiliency in service for current customers, toward zero-emission communities. The proposed community microgrid would improve power supply reliability and resiliency and provide a clean, green energy service for current communities and customers.

Following Section 3 (Task 2), a preliminary technical design and system configuration was proposed for WPMRS per the site assessment findings and characteristics identified in Task 2. The proposed microgrid infrastructure and operations were presented to both utility and stakeholders. The load characteristics of different stakeholders and aggregated hourly load profiles for the WPMRS were calculated and summarized. Solar-Battery combined solution to be operated in the WPMRS were studied and



summarized for each of the sites (**Table 16** to **Table 18**), resulting in a total of 1.16MW solar PV and 2.44MWh battery for resiliency or 660kWh battery for the economic scenario. The preliminary costs and relevant CO₂ emissions are calculated for both the current system, i.e., base scenario, and for the proposed systems, i.e., base scenario and the proposed solution.

An optimization-based DER Planning model developed by Willdan is applied for the optimal DER mix calculation by considering the hourly load shape, electricity tariff, resiliency expectation, historical weather data, historical outages, etc. Based on the calculation results, the WPMRS distribution system has the potential to benefit from investments in microgrids and DER technologies. Solar PV and battery storage enable the proposed community microgrid to operate in islanded mode during power grid outages or in extreme conditions, improving the overall power supply quality and increasing reliability and resiliency for the whole community, adding an extra layer of protection in addition to the existing backup generators. The coordination between solar generation and battery operation would maximize economic benefits while also considering resiliency and environmental benefits and reducing the system's dependency on natural gas, which may be unavailable during extreme conditions such as storms, heatwaves, floods, etc.

The current annual energy costs and CO₂ emissions for the existing loads are calculated to be \$760 thousand and 1,454 metric tons, respectively. This represents the baseline for the proposed microgrid solution. After considering the electricity tariff, new DER mix, load shape, etc., into the planning model, the proposed community microgrid would have a 43.4% annual energy cost saving and 21% annual CO₂ emissions saving compared with the base case. Additionally, the annual CO₂ emission reduction compared to the base case is 303 metric tons.

5. Financial Solutions

5.1 Financial and Economic Analysis Objectives

The proposed project includes solar PV and battery storage DERs and other efficiency enhancements within the microgrid system. The installation would seamlessly integrate key objectives of the CLEAR Program (described above) and the City's Municipal Vulnerability Preparedness (MVP) plan (2019), which identified initiatives to increase resiliency and reduce impacts from utility outages, GHGs, and energy costs.

5.2 Microgrid Development & Investment Trends

To inform the City of Framingham's evaluation of microgrid installations on public property, the following overview of development and investment trends provides a brief history of the geographic expansion, purposes, and ownership structures that influence the current state of the microgrid market.

5.2.1 History of U.S. Microgrid Development


According to U.S. Department of Energy (DOE) data²⁴ illustrated in **Figure 32** and **Figure 33**, there are approximately 461 active microgrid projects in the United States containing 821 distributed energy resources (DERs). Texas leads the nation in installations, followed by California, New York, Hawaii, and

²⁴ <https://doe.icfwebservices.com/microgrid>




Massachusetts. Combined, these states and the Commonwealth account for nearly 60 percent of the total installations in the U.S. and its territories.

Figure 32. Active U.S. Microgrid Projects by Year of Construction



Source: <https://doe.icfwebservices.com/microgrid>; Willdan, 2021

Figure 33. Active U.S. Microgrid Projects by State



Source: U.S. Department of Energy; Willdan, 2021

Commercial deployments are the largest setting for microgrids, accounting for 42 percent of the U.S. total. This figure is skewed by the development of microgrids by H-E-B supermarkets in Texas, which began deploying microgrids in the Houston market to address power-related operational costs (spoilage).

The aftermath of Hurricane Harvey (late August 2017) tested the chain’s ability to maintain operations at multiple Houston stores for several days following that event. Even the storm knocked out power for 300,000 utility customers²⁵. Eighteen stores received full-facility backup power for five consecutive days during the storm. This led to the expansion of its microgrid program across the company, marketing “reliability as a service.”

Table 20. U.S. Microgrid Installation Settings

	U.S. Total	%	Total w/o TX	%
Commercial	194	42%	51	17%
City/Community	57	12%	55	19%
Military	49	11%	47	16%
College/University	44	10%	41	14%
Schools	27	6%	27	9%
Hospital/Healthcare	22	5%	19	6%
Public Institution	16	3%	16	5%
Research Facility	16	3%	13	4%
Multi-Family	15	3%	14	5%
Water Treatment/Utility	9	2%	2	1%
Agriculture	8	2%	8	3%
Other	4	1%	4	1%
TOTAL	461	100%	297	100%

Source: U.S. Department of Energy; Willdan, 2021

Excluding the Texas data, commercial, city/community, military, and college/university deployments are the primary settings, accounting for approximately two-thirds of the 297 microgrids in the remainder of the U.S.

Natural gas [turbines] are the most common energy resource, totaling 191 and accounting for 23 percent of all microgrid resources. Within this total, there are 121 H-E-B natural gas microgrids in Texas.

Outside of Texas, natural gas totals 41, or 6 percent of the total U.S. microgrid energy resources. Dominant technologies are solar and [battery] storage, accounting for more than half the non-Texas total.

Table 21. U.S. Microgrid Total Distributed Energy Resources

	U.S. Total	%	Total w/o TX	%
Natural Gas	191	23%	41	6%
Solar	181	22%	175	27%
Storage	171	21%	165	26%
CHP	102	12%	98	15%
Diesel	92	11%	82	13%
Wind	35	4%	35	5%
Fuel Cell	15	2%	15	2%
Unknown	13	2%	13	2%

²⁵ <https://microgridknowledge.com/h-e-b-microgrid-hurricane/>



Biogas	13	2%	13	2%
Hydro	5	1%	5	1%
Thermal	<u>3</u>	<u>< 1%</u>	<u>2</u>	<u>< 1%</u>
Total	821	100%	644	100%


Source: U.S. Department of Energy and Willdan, 2021

5.2.2 Microgrid Funding Trends

To evaluate microgrid financing alternatives, Willdan conducted case study research on 93 microgrid projects throughout the U.S. The research concluded that the most common form of financing is the Power Purchase Agreement (PPA).

Of those with detailed funding information, nearly half of all microgrid project deals utilized a combination of grant and PPA financing. Another 23 percent utilized a combination of grant and loan funding, while 18 percent included a combination of self-funding and grants, as shown in **Figure 34**.

Figure 34. Volume of Microgrid Project Deals by Funding Source




On a dollar volume basis, the following figure illustrates that PPAs are the dominant funding source in the industry, providing 97% of the total capital investment analyzed within the case study projects (the sum of PPA & Loan Funding plus Grant & PPA Funding).

The disparity between the distribution of deals by funding category and the quantity of capital deployed perhaps exposes the challenge of raising capital outside of a PPA structure, or conversely, the relative ease of PPA financing. In the rare cases where non-PPA sources are utilized, the data indicate that the deals have much smaller capital needs.



Figure 35. Volume of Microgrid Dollars Invested by Funding Source



5.2.3 Trends in Ownership Structures

By virtue of the dominance of PPA financing, third-party ownership is the most common structure. A PPA is the only ownership structure that would enable a public entity to participate in downstream benefits from federal incentives. The importance of the federal investment tax credits and depreciation benefits cannot be overstated as a key consideration for the ownership structure. These items represent significant potential sources of investment cash flow that are not available to the public sector.

Every funding mechanism has the pros and cons. Elements of traditional infrastructure funding mechanisms (i.e., Special-Purpose Vehicles, Build-Operate-Transfer (BOT) models, and Public-Private Partnerships (PPPs)) are embodied within the agreements themselves, and are unwieldy for the projects studied in this report.

For example, PPA agreements may stipulate buy-back provisions at key junctures, likening them to a BOT. Special-purpose vehicles are generally unnecessary, as their primary benefit of moving the investment transaction “off balance sheet” is de facto accomplished by a PPA or other third-party mechanism.

PPPs are more typically deployed for very complex projects with significant capital needs (\$100M+) and timelines that are often multiple times longer than PPA deal terms, which typically run for 20 years or less.

5.3 Potential Funding Alternatives

5.3.1 Direct Funding

Ownership through direct funding via the Capital Improvement Planning (CIP) and/or General Fund (GF) could include a mix of capital sources, including direct budget appropriations, general obligation bonds, revenue bonds, grants, green bonds, and other opportunities that are described below (refer to Appendix B: State & Federal Grant Programs, Incentives, and Capital Enhancements for detailed background information).



Direct public ownership allows the owner (City) to fully realize the full operational revenue stream and direct the deployment of those assets (i.e., how the energy resources are used), but eliminates the substantial benefits arising from federal investment tax credits (see ITC description) and depreciation. Debt and budget capacities are also substantial considerations, as these sources are not always readily available. The expertise and manpower to maintain and operate the microgrid are still another concerns or constraints, as Public Works Departments may not possess the knowledge, skills, or expertise to effectively execute, or must invest in human capital to do so.

Direct funding can be enhanced utilizing a variety of available tools to supplement investment capital, or more often, enhance or guarantee borrowing terms that facilitate the flow of capital.

5.3.2 Third-Party Funding Mechanisms

In addition to traditional funding through a combination of public debt and equity, there are financing mechanisms that utilize third-party capital, but shift ownership and most, if not all, operational control as well. These structures include Energy Services Agreements, recently enacted Massachusetts SB-9, PACE financing, and the more commonly deployed Power Purchase Agreement (PPA). Each of these is described in further detail below and in Appendix B: State & Federal Grant Programs, Incentives, and Capital Enhancements.

Power Purchase Agreement

A PPA is a financial agreement where a developer arranges for the design, permitting, financing and installation of an energy system on a customer's property at little to no upfront capital cost. The developer sells the power generated to the host customer at a fixed rate that is typically lower than the local utility's retail rate. This lower electricity price serves to offset the customer's purchase of electricity from the grid while the developer receives the income from the sale of electricity, as well as any tax credits and all incentives generated from the system, unless modified contractually.

PPAs typically range in duration from 10 to 25 years and the developer remains responsible for the operation and maintenance of the system for the duration of the agreement. At the end of the PPA contract term, a customer may be able to extend the PPA, have the developer remove the system or choose to buy the solar energy system from the developer.

PPAs are one of the most common forms of financing infrastructure because there is usually a high upfront cost that the host cannot afford. Choosing a PPA also means that the host is not responsible for the maintenance and saves money throughout the PPA. However, usually at the end of the leased agreement, the infrastructure has reached its useful life and needs to be replaced, so the host does not benefit much after the PPA.

The PPA provider is the owner of the assets through the term of the agreement and will seek to retain future incentive savings from programs that do not currently exist. This may preclude the host's ability to claim environmental benefits against targets (e.g., greenhouse gas reductions or carbon markets).

As these deals are typically longer term, consideration should also be given to the host's ability to affect future changes to buildings or property where the assets are sited.



Energy Services Agreement

An Energy Service Agreement (ESA) is a pay-for-performance, off-balance sheet financing solution that allows customers to implement energy efficiency projects with no upfront capital expenditure. Through the ESA, the ESA provider pays for all project development and construction costs. Once a project is operational, the customer makes service charge payments for actual realized savings. The price per unit of savings is a fixed output-based charge that is set at or below a customer's existing utility price, resulting in immediate reduced operating expenses.

Unlike a PPA, customers do not assume performance risk since they only pay for the actual savings. Instead, the ESA provider takes the project performance risk and gets paid less if the project savings are less than expected.

Generally, an ESA is an effective tool for property owners looking to stabilize utility costs and make progress on their corporate social responsibility goals without making a large capital outlay. While ESAs offer long-term benefits due to the ability to buy out the contract and take ownership of the installed equipment, their primary benefit is the flexible nature of the contract structure. An ESA provides the host entity an opportunity to reduce energy consumption within facilities with minimal management and little to no upfront costs.

Massachusetts SB-9

In March 2021, Governor Baker signed Massachusetts Senate Bill 9 (SB-9) legislation into law. The bill outlined comprehensive climate change legislation to meet the Commonwealth's commitment to achieving net zero emissions by 2050 and interim targets of 50 percent by 2030 and 75 percent by 2040. The legislation also authorizes the Secretary of Energy and Environmental Affairs (EEA) to establish emissions limits every five years and sector limits for electric power, transportation, commercial and industrial heating and cooling, residential heating and cooling, industrial processes, and natural gas distribution and service.

Other provisions of the bill:

- Increase the percentage of electricity from renewable sources by 3% annually between 2025 and 2029 to achieve a 40% overall target by 2030
- Raise the state's total target of offshore wind to 5,600 MW by authorizing 2,400 additional MW of additional capacity
- Improve access to solar for low-income communities by establishing a solar program trust
- Enhance gas pipeline safety
- Create a pilot program to deploy geothermal heat pumps within micro-districts
- Include the importance of equity and reductions in greenhouse gas emissions among the Department of Public Utility's existing priorities for safety, security, reliability, and affordability
- Require municipal light plants, which serve specific cities or towns, to purchase 50% of their power from non-carbon sources by 2030 and achieve net-zero emissions by 2050
- Provide local property tax exemptions under certain situations (see Local Property Tax Exemption)



A pertinent element of SB-9 is a provision that makes electric and gas distribution companies eligible to assist a municipality at high risk from climate change by constructing, owning, and operating solar PV and energy storage facilities on land owned by the electric or gas distribution company within a municipality. Focus is given to those municipalities with environmental justice populations. These facilities are built at no cost to the town and may receive DPU approval for cost recovery.

This change is significant, as distribution companies were previously prohibited from owning generation assets. The provision also limits the amount of energy to 10 percent of the total installed megawatt capacity of the Commonwealth's solar generation facilities as of July 31, 2020.

Petitions for the development and cost recovery of utility-owned solar facilities must demonstrate site-specific environmental or climate change benefits to the community, municipality, or the Commonwealth. They are required to demonstrate consistency with the Commonwealth's energy policies, contribute to the climate change resiliency of the host municipality, and mitigate peak energy demand.

At the time of this writing, there are no known petitions or completed developments for utility-owned solar PV installations or associated battery storage. Importantly, the ability of a municipality to direct the energy produced to any single asset or location(s) may be limited in this ownership context.

PACE

The Property Assessed Clean Energy (PACE) model is an innovative mechanism for financing energy efficiency and renewable energy improvements on private property. PACE programs exist for commercial properties (C-PACE) and residential properties (R-PACE). PACE programs allow a property owner to finance the up-front cost of energy or other eligible improvements on a property and then pay the costs back over time through a voluntary assessment. The unique characteristic of PACE assessments is that the assessment is attached to the property rather than an individual.

PACE financing for clean energy projects generally is based on an existing structure known as a "land-secured financing district," often referred to as an assessment district, a local improvement district, or other similar phrases. In a conventional assessment district, the local government issues bonds to fund projects with a public purpose such as streetlights, sewer systems, or underground utility lines.

The recent extension of this financing model to energy efficiency and renewable energy allows a property owner to implement improvements without a large up-front cash payment. Property owners that voluntarily choose to participate in a PACE program repay their improvement costs over a set period—typically 10 to 20 years—through property assessments, which are secured by the property itself and paid as an addition to the owners' property tax bills. Nonpayment generally results in the same set of repercussions for failure to pay any other portion of a property tax bill, including loss of property.

5.3.3 Grants and Capital Enhancements

Following is a summary list of grant funding programs and cost-of-capital reductions. The detailed descriptions of their purposes, eligibility criteria, and other details are provided in Appendix B: State & Federal Grant Programs, Incentives, and Capital Enhancements.

- Biden Bipartisan Infrastructure Law (Infrastructure Investment and Jobs Act 2021)



- Building Resilient Infrastructure and Communities (BRIC) Grants
- DOE Loan Guarantees
- EPA Grants
- Green Bonds
- Green Banks
- Massachusetts Clean Water Trust
- Property Assessed Clean Energy (PACE)
- Massachusetts SB 9 (Net Zero Emissions by 2050)

5.4 Operational Benefits, Incentives, and Other Cash-Flow Opportunities

Energy companies and ISOs (see ISO) often maintain a variety of market-based opportunities that can monetize microgrids and their energy resources. It could be as simple as a solar PV array selling energy directly into the grid or as complicated as demand response (peak shaving), where energy is actively managed (called) to ensure adequate energy supplies and to balance energy loads on the grid.

Specific to the WPMRS, it is anticipated that the secondary market opportunities will likely focus on the Clean Peak Energy Credits (CPECs) Program and Demand Response, where the full, available capacity of both the solar PV and battery energy storage can be utilized for both purposes simultaneously, eliminating mutual exclusivities that arise with other options.

In addition, third-party ownership will enable the capture of Federal ITCs and depreciation benefits. Several additional secondary market opportunities that could generate financial benefits are less likely and more complicated due to mutual exclusivity challenges associated with the deployment of the stored battery energy and increased operational complexity. These challenges would not necessarily preclude participation but make it less likely given the financial upside of the “more likely” programs listed above. These additional opportunities detailed in Appendix A: Financial Analysis – Glossary of Terms include:

- Black Start Support
- Curtailment
- Clean Peak Energy Credits
- Depreciation
- Local Property Tax Exemptions
- Forward Capacity Market (FCM) Savings
- Frequency Regulation
- Regional Network Services (RNS)
- Reliability/Resiliency
- SMART Solar Incentives

5.5 City of Framingham Financing Requirements

Following data collection interviews with City staff, Willdan validated the City’s key financial objectives to limit upfront capital outlays and ongoing operating responsibilities associated with microgrid development.



Based on these established funding plan parameters, third-party financing through a PPA is the recommended source of project capital. The following financial analysis is based on this understanding and provides the respective deal terms for the City of Framingham and a PPA provider.

This analysis is structured to identify key financing assumptions and deal terms and, potentially, areas of negotiation for the City.

5.6 Capital Cost Estimate

Capital costs are estimated from system sizing parameters presented in Section 4 and the current market cost per KW of capacity. These estimates assume that a third-party provider may be able to gain some volume purchasing power but will likely fall between the costs published in National Renewable Energy Laboratory’s (NREL) *Annual Technology Baseline* report and general consumer pricing.

According to the NREL report, median solar PV costs for larger commercial applications decreased from \$8,500 per kW in 2007 to \$1,762 per kW in 2020, reflecting a 79 percent overall decrease and an average annual reduction of just under 13 percent per year.

Future annual cost reductions are estimated to range between 2.0% and 9.0% for NREL’s conservative and aggressive estimates, respectively, through 2030. Thereafter, reductions range between 1.0% and 2.0% percent, reflecting the maturation of the market and the more conservative nature of long-range projections in a rapidly evolving technology space.

NREL’s average price estimate for future battery energy storage reflects a similar level and pattern of reductions with the unit cost for large-scale commercial applications decreasing from \$1,762 per KW in 2020 to just over \$1,000 by 2030, and \$870 by 2040.

The estimated hard costs for the WPMRS are higher than the NREL research but, importantly, include necessary microgrid components such as inverters, software, and other ancillary items. Moreover, it is assumed that a PPA provider’s purchasing power would not rise to the level of large commercial installations, lending a more conservative bias to the analysis.

Interconnection fees are separately estimated based on very preliminary discussions with Eversource. It is important to note that this cost estimate may be subject to modification by the energy company based on the final system specifications and a more comprehensive review of capacities impacted by the microgrid development.

Future reinvestment costs are modeled at the end of the estimated useful life for each asset and include an average year-over-year cost reduction of 3.0 percent and 3.5 percent for solar PV and battery energy storage resources, respectively. Baseline inputs are as follows:

Solar Photovoltaic	\$3,000/kW
Battery Energy Storage (4-hr rating)	\$2,300/kW

Timing for the proposed improvements include investment and operation commencing in 2022, with 30 percent of the operational capacity realized in 2022 (i.e., all DERs operating over approximately the last one-third of the year, considering the time of installation and interconnection process until the full capacity can function).



Total hard costs are estimated at \$3.9 million including installation cost, exclusive of a 30 percent soft cost estimate and interconnection fees that increase estimated total capital expenditures to \$5.1 million.



Table 22. Key Timing and Sizing Assumptions and Estimated Capital Costs

Timing Assumptions		FHS	FS2	PS	Total
Investment Year/Construction Start		2022	2022	2022	
First Operational Year		2022	2022	2022	
1st Year Operational Capacity %		30%	30%	30%	
Microgrid Capacity Inputs					
Solar PV	kW	1,060.0	52.8	51.2	1,164.0
Battery Output	KW	125	15	25	165
Battery Energy Storage (4-hr rating)	kWh	500	60	100	660
Capital Cost Estimate					
Solar PV		\$3,180,000	\$158,400	\$153,600	\$3,492,000
Battery Energy Storage (4-hr rating)		\$287,500	\$34,500	\$57,500	\$379,500
Interconnection Fees					<u>\$70,000</u>
				Subtotal	\$3,941,500
Project Overhead @30%					\$1,161,450
Total Estimated Cost					\$5,102,950

Source: Willdan, 2021

Other Battery-Related Sizing Considerations

The size relationship between the battery energy storage and solar photovoltaic resources, aside from the general energy strategy, has several financial implications that were considered and evaluated.

The Investment Tax Credit benefit is perhaps the most significant. It requires that the battery be charged at a minimum of 75% from renewable sources. The actual ITC benefit for a battery depends on the percent of the time the battery is charged by combined solar. Above 75%, the amount of the ITC is reduced to the actual percentage. For example, a system charged by renewable energy 80% of the time is eligible for the 30% ITC multiplied by 80%, which equals a 24% ITC instead of 30%²⁶. Below, the benefit is zero.

Similarly, this relationship impacts the Clean Peak Energy Credits calculation, which requires a 75% charging threshold from renewable sources to realize those benefits.

These relationships indicate diminishing financial benefits when the battery is oversized relative to its renewable charging source. Third-party owners will most likely seek to optimize this relationship to maximize the financial returns.

Specific to the recommended programs for the Winch Park site, the system elements and their relative sizes all possess the theoretical capacities to exceed 100 percent battery energy storage charging from their associated solar photovoltaic arrays and would maximize the ITC benefit potential for owners that incur a federal tax liability.

²⁶ <https://www.nrel.gov/docs/fy18osti/70384.pdf>



5.7 Financial Analysis

The financial analysis is structured to profile the perspective of the City of Framingham entering into third-party owner/operator agreements for the microgrid improvements. This perspective is based on feedback and guidance from the City after consideration of available financial resources, lack of capacity to operate and maintain the assets, and other related factors.

It is anticipated that the City of Framingham will execute Power Purchase Agreements (PPAs) for the solar PV assets and/or Energy Services Agreements (ESAs) for the battery energy storage assets. The estimated sources of financial inflows (revenues, tax credits, expense savings, etc.) and outflows (operational costs) are summarized in **Table 29** and **Table 30**.

5.7.1 Key Assumptions

The following key assumptions underlie the financial analysis:

Inflation/Deflation: All estimates are presented in constant value 2021 dollars.

Solar PV Output: Energy output from the Winch Park microgrid’s solar PV arrays is a function of both the relatively fixed engineering of the installed solar panel and the variability of sunlight, the latter dictated primarily by geographic location and orientation of the system to the sun. These variable elements are the primary definers for a location’s “solar shape,” data that is gathered from Folsom Lab’s web-based subscription service Helioscope (www.helioscope.com). This service provides location-specific solar energy potentials across all 8,760 hours in a year at a given geographic location, enabling the calculation of total annual energy potential or more granular detail, such as output during defined peak hour periods.

Energy Resource Performance Degradation: Solar PV energy output and battery energy storage performance does not remain constant year over year. They slowly degrade with time, with batteries susceptible to higher levels of degradation with increased “cycling” or charging/discharging. Solar degradation is typically slower, constant, and more a function of wear and tear over time. Solar PV energy output and battery storage performance, for the purposes of the financial analysis, are modeled to degrade by 0.5% and 1.0% per year over their estimated useful life, respectively. These factors are both well within actual performance ranges.

Capital Reinvestment: Capital reinvestment is modeled at the end of each asset’s useful life, with assumed annual reductions in pricing, as detailed in the capital investment section and summarized below.

	Est. Useful Life	CapEx Price Reduction per Yr.
Solar PV	25 yrs.	-3.0%
Battery Energy Storage (4-hr rating)	12 yrs.	-3.5%

Term: All financial estimates are modeled over a 20-year horizon.



5.8 Revenue and Other Financial Inflows

5.8.1 Investment Tax Credit

The value of the investment tax credit (ITC) is dependent on the timing of construction start, not operations. The ITC benefits are under constant evaluation and have been subject to prior extensions. Pending federal legislation could further adjust the percentage and/or timing of the ITC benefits as well. Consideration of this variability within a PPA or similar agreement may be warranted, as the value potential is substantial.

The current schedule for the ITC (based on construction start) is as follows:

Year	Commercial
2021	26%
2022	26%
2023	22%
2023+	10%

The financial model presented herein assumes that construction would commence prior to the end of 2022, creating a benefit for federal tax liable entities equal to 26 percent of project capital expenditures.

In addition, the energy output from the solar PV arrays in all Winch Park energy resource locations exceeds 100% of collocated battery charging requirements, indicating the potential to maximize the battery ITC as well.

The value of the investment tax credit is estimated to total just over \$900,000 in current value dollars. The early timing and amount of cash flow are important investment considerations, as the amount exceeds the net operational proceeds (\$709,000) generated in a stabilized year by the three Winch Park locations.

5.8.2 MA SMART Solar Program Incentive Payment

As described in the overview of the Commonwealth’s SMART Solar Incentive Program in **Appendix A: Financial Analysis – Glossary of Terms**, the development of clean energy resources generates a substantial incentive opportunity to their owners. The WPMRS was evaluated utilizing DOER’s Value of Energy and Incentive Calculator. The calculator considers project type, size, distribution company service territory, customer rate class, and capacity block.

SMART incentive amounts for the WPMRS resources ranged from \$0.25 to over \$0.31 per kWh of solar PV energy output.

The duration of the incentive is based on total capacity output, with those exceeding 25 KW AC provided a 20-year benefit, all others receiving a 10-year benefit.

Table 23. SMART Solar Incentive Rates

	FHS	FS2	PS
SMART Solar Base Generation Rate (\$/kWh)	\$0.15883	\$0.21658	\$0.21658
Location Adder (\$/kWh)	\$0.01920	\$0.01920	\$0.01920
Off-Taker Based (\$/kWh)	\$0.03064	\$0.03064	\$0.03064



Energy Storage Adder (\$/kWh)	\$0.04070	\$0.04460	\$0.04470
Total SMART Solar Payment (\$/kWh)	\$0.24937	\$0.31102	\$0.31112
SMART Duration of Benefits	20 Years	10 Years	20 Years

Source: MA SMART Solar Calculator and Willdan Financial Services, 2021

Total value of the SMART solar payment is estimated at just under \$385,000 per year, calculated on the estimated annual solar at each location and totaling 1.51 million kWh across the entire microgrid.

5.8.3 On-Bill Savings

On-bill savings are calculated utilizing Integral Analytics’ *Site Optimizer*, a comprehensive DER sizing and support tool for integrating renewable energy investments.

Dollar value benefits are calculated by comparing the customer’s current load profile against a solar load shape. This estimate utilizes the customer’s current total electricity tariff (demand charge price, energy price, and basic meter charges), considering both peak/off-peak hours and winter/summer seasonal pricing variations.

Battery benefits are isolated by calculating energy savings and demand charge reductions for the entire system, then subtracting the calculation for those benefits arising from solar alone. These cash values are then converted to a \$/kWh value for calculation against the quantity of energy produced (solar PV) or energy stored (battery), capturing the degradation factor in the financial output.

Stabilized year estimates for on-bill savings total just under \$270,000 annually. From a practical perspective, the solar PV array is the primary source of energy savings, while the battery is responsible for almost the entirety of demand charge savings, again highlighting the importance of this resource’s ability to shift/lower demand during peak consumption periods.

5.8.4 PPA Solar PV Energy Payment from Host to Provider

Under the anticipated PPA structure, the Host/City would likely be contractually obligated to purchase the energy produced by the solar PV array(s) from the PPA provider. For the purposes of calculating this value, a price of \$0.125 per kWh was assumed, representing a discount of approximately \$0.05 per kWh over the current average energy price for the microgrid sites. In a typical year, this equates to just under \$189,000 that is paid to the provider. A corresponding outflow, representing the Host/City perspective, is detailed in the description of outflows later in this section of the report.

5.8.5 Demand Response (aka Connected Solutions)

Demand response is currently valued by Eversource Energy at \$225 per kWh of battery capacity. Based on recommended system parameters, this equates to an estimated annual value of \$49,500 across the three WPMRS sites.

5.8.6 Clean Peak Energy Credits

The calculation of Clean Peak Energy Credits (CPECs) is based on program parameters that delineate “multipliers” for each megawatt of energy produced during certain defined time periods during “normal” days and the “monthly peak” day.



Table 24. CPEC Seasonal and Time of Day Windows

Season Date and Times	Begin	End	Days in Season	Seasonal Peak Days	Monthly Peak Days	Peak Hours (between these values)
Spring	1-Mar	14-May	75	73	2	5:00 PM to 9:00 PM
Summer	15-May	14-Sep	123	119	4	3:00 PM to 7:00 PM
Fall	15-Sep	30-Nov	77	74	3	4:00 PM to 8:00 PM
Winter	1-Dec	28-Feb	90	87	3	4:00 PM to 8:00 PM
			365	353	12	

Source: 225 CMR: MA Department of Energy Resources

The multipliers encourage participation by greatly increasing the quantity of CPECs and the economic value by increasing value when demand is highest. One additional positive multiplier is available for systems that enhance resiliency (1.5x), while others reduce the quantity of CPECs generated. This latter group includes resources already benefitting from SMART solar benefits (0.3x, applicable to the Solar PV arrays), the existing resource multiplier (0.1x), and the contracted resource multiplier (0.01x). These last two are not applicable to the CPEC calculations for the WPMRS.

Table 25. CPEC Multipliers

Day Type	Seasonal Day Type	Seasonal Multiplier	Monthly Peak Multiplier	Resilience Multiplier	Existing Resource Multiplier	Contracted Resource Multiplier	SMART ES Resource Multiplier
Normal Days	Spring Normal Day	1	1	1.5x	0.1x (Not applicable to this microgrid)	0.01x (Not applicable to this microgrid)	0.3x (Applicable only to solar PV energy)
	Summer Normal Day	4	1				
	Fall Normal Day	1	1				
	Winter Normal Day	4	1				
Monthly Peaks	Spring Peak Day	1	25				
	Summer Peak Day	4	25				
	Fall Peak Day	1	25				
	Winter Peak Day	4	25				

Source: 225 CMR: MA Department of Energy Resources

The WPMRS is estimated to generate 1,590 CPECs annually, presented in the table on the following page.

The market value of these CPECs is estimated at \$71,500 at the current \$45 Alternative Compliance Payment (ACP)²⁷. The value of CPECs is estimated to decline, both as a factor of output degradation and the planned \$1.54 annual reduction in the ACP commencing in 2025. This value may further shift (up or down) as the ACP price is adjusted through an annual review process and the number of CPECs issued. Oversupply relative to CPEC targets will generate small price decreases, while conversely, undersupply will raise the price, increasing the economic rationale for clean energy resource investment.

²⁷ <https://www.mass.gov/service-details/annual-compliance-information-for-retail-electric-suppliers>



Table 26. Estimated Clean Peak Energy Credits

		Solar PV			Battery Energy Storage			
		Peak Hour (kWh)	Daily CPECs	Annual CPECs	Discharge (kWh) ²⁸	Daily CPECs	Annual CPECs	Total CPECs
Normal Days	Spring Normal Day	224.6	0.1	7.4	561.0	0.8	61.4	68.8
	Summer Normal Day	1,179.2	2.1	252.6	561.0	3.4	400.6	653.1
	Fall Normal Day	174.0	0.1	5.8	561.0	0.8	62.3	68.1
	Winter Normal Day	157.2	0.3	24.6	561.0	3.4	292.8	317.5
Monthly Peaks	Spring Peak Day (2 days)	224.6	2.6	5.3	495.0	6.9	13.9	19.1
	Summer Peak Day (4 days)	1,179.2	55.2	220.8	495.0	27.7	110.9	331.6
	Fall Peak Day (3 days)	174.0	2.0	6.1	495.0	6.9	20.8	26.9
	Winter Peak Day (3 days)	157.2	7.4	22.1	495.0	27.7	83.2	105.2
Grand Total								1,590.4

Source: Willdan Financial Services, 2021

5.8.7 Depreciation

Depreciation represents a significant source of value to the owner’s subject to federal income tax. As detailed in depreciation opportunities, the timing and selected depreciation methodology (Bonus vs. MCARS 5-year) can drive significant differences in value for the project.

For simplicity purposes and assuming an opportunity to claim 100 percent bonus depreciation (i.e., claimed in 2022), the difference in net present value when claiming the bonus, versus spreading the benefit over five years, generates an estimated net present value benefit of more than \$76,500 (@ 8.25% discount rate).

5.9 Expenses and Other Outflows

5.9.1 Operations and Maintenance Expenses

Ongoing operations and maintenance expenses are estimated utilizing NREL research. Costs are estimated at \$18 per KW for solar PV resources and \$45 per KW for battery resources. Annual O&M expenses total just over \$50,000 per year, with just under 60% attributed to the battery components.

5.9.2 Host Solar PV Energy Payment to PPA Provider

An ongoing, contractual cost of any PPA agreement is the commitment to purchase solar PV energy at a fixed annual rate. While the cost per kWh is anticipated to be a negotiated element of a PPA agreement, the financial model assumes an energy value of \$0.125. This equates to an annual payment of just over

²⁸ Using battery for other avenue stream could impact the resiliency service negatively. The impact could be alleviated by close collaboration with location utility and emergency management department.



\$188,000, based on nameplate capacity combined with historical solar radiation data in this area, by the City/Host to the PPA provider.

5.9.3 Battery Round-Trip Energy Loss

Round-trip energy costs reflect the net expense associated with recharging a battery storage energy resource. The expense reflects the fact that the amount of energy needed to charge a battery is more than the amount of energy that is discharged. Round-trip efficiency is estimated at 80 percent. The value of the loss is equated using the average SMART solar rate across the entire project. The dollar value of this expense is estimated at just under \$14,000 in a stabilized year.

5.10 Net Operating Revenues (Stabilized Operations)

Net operating revenue, exclusive of the ITC and depreciation benefits, is estimated at \$710,000. This total includes \$964,000 in operational inflows against \$254,000 in direct operating expenses. This value excludes consideration of the timing of benefits and represents a snapshot of performance based on the nameplate or theoretical capacities of the energy resources.



Table 27. Stabilized Year Statement

Microgrid Capacity Inputs	Accrues to:	Framingham HS	Fire Dept. No. 2	Pump Station	Total
Solar PV (kW)		1,060	53	51	1,164
Battery Energy Storage (4-hr rating) (kWh)		500	60	100	660
Battery Power (KW)		125	15	25	165
Battery Power (MW)		0.13	0.02	0.03	0.17
Annual Solar Generation (kWh)		1,374,299	68,456	66,381	1,509,136
Initial Capital Investment					
Solar PV	Provider	3,180,000	158,400	153,600	3,492,000
Battery Energy Storage (4-hr rating)	Provider	287,500	34,500	57,500	379,500
Interconnection & Infrastructure Upgrades	Provider	62,695	3,488	3,817	70,000
Project Administration/Overhead (30% of hard costs)	Provider	1,040,250	57,870	63,330	1,161,450
Total Initial Capital Investment		\$ 4,570,445	\$ 254,258	\$ 278,247	\$ 5,102,950
Operating Inflows					
MA SMART Solar Program Incentive Payment 3/	Provider	342,709	21,291	20,653	384,653
On-Bill Savings - Demand Charge	Split	69,384	3,869	7,493	80,746
On-Bill Savings - Energy Charge	Host	168,515	10,328	9,726	188,569
PPA Solar PV Energy Payment from Host to Provider 4/	Provider	171,787	8,557	8,298	188,642
Demand Response aka Connected Solutions	Split	37,500	4,500	7,500	49,500
Clean Energy Peak Credit-Solar PV	Split	22,316	1,112	1,078	24,506
Clean Energy Peak Credit-Battery Storage	Split	35,652	4,278	7,130	47,060
Total Operating Inflows		\$ 847,865	\$ 53,935	\$ 61,877	\$ 963,677
Operating Outflows					
Operations & Maintenance Expenses					
Solar PV	Provider	\$ 19,080	\$ 950	\$ 922	\$ 20,952
Battery Energy Storage (4-hr rating)	Provider	22,500	2,700	4,500	29,700
Total Operations and Maintenance		\$ 41,580	\$ 3,650	\$ 5,422	\$ 50,652
Host Solar PV Energy Payment to PPA Provider 4/	Host	\$ 171,787	\$ 8,557	\$ 8,298	188,642
Battery Round Trip Energy Loss	Split	\$ 11,266	\$ 1,352	\$ 2,253	14,871
Total Operating Outflows		\$ 224,633	\$ 13,559	\$ 15,972	\$ 254,165
Net Operating Cash Flow		\$ 623,231	\$ 40,376	\$ 45,905	\$ 709,511
Investment Tax Credit					
Solar PV Investment Tax Credit (ITC) 1/	Provider	\$ 1,089,789	\$ 54,284	\$ 52,639	\$ 1,196,712
Battery Storage Investment Tax Credit (ITC) 1/ 2/	Provider	98,527	11,823	19,705	130,055
Total ITC		\$ 1,188,316	\$ 66,107	\$ 72,344	\$ 1,326,767
Depreciation 5/					
Bonus Depreciation Percentage		100%	100%	100%	
Bonus Depreciation Taxable Basis		2,873,342	159,846	174,928	3,208,117
MACRS Taxable Basis 6/		-	-	-	-
Depreciation Benefit @ 22% Federal Tax Rate	Provider	632,135	35,166	38,484	705,786
Net Cash Flow after ITC and Depreciation		\$ 2,443,682	\$ 141,649	\$ 156,733	\$ 2,742,064

1/ Investment Tax Credit percent is 26.0% if construction commences in 2021 or 2022, 22.0% in 2023, and 10.0% thereafter.

2/ Battery must receive a minimum of 75% of charging over the entire year from renewable sources; tax credit is then proportioned by the percentage of power 75% or higher.

3/ MA Smart Program Incentive duration is 10 years for systems ≤ 25 kW AC or 20 years for systems >25 kW AC.

4/ PPA Energy Payment \$0.125 per kWh

5/ Bonus depreciation capture requires all assets be depreciated under this methodology; if bonus amount is less than 100 percent, any remainder is depreciated under MACRS schedule.

6/ MACRS depreciation schedule is variable year-to-year; this basis (less one-half of the federal ITC) is calculated using the annual average of 16.67 percent.

7/ Model assumes zero (\$0) residual value of assets at end of useful life

Source: Willdan Financial Services, 2021



5.11 Multi-Year Financial Analysis

The multi-year presentation of estimated cash flows presents a clearer understanding of the benefits over time and allows for the incorporation of the important ITC and depreciation tax advantages that comprise significant elements of overall project value over a 20-year term.

Moreover, the analysis provides an opportunity to segregate estimated revenues and expenses to the City/Host, PPA provider, or split the values between the parties and then evaluate the relative position of each from a total cash flow and discounted cash flow perspective. Lastly, the model provides the opportunity to test variables and modify assumptions to understand the relative position of each party and identify terms that could be negotiated that would continue to provide adequate (although lower than targeted) returns to a PPA provider.

As noted earlier, ITC and depreciation benefits have specific time parameters. These values are modeled to achieve their maximum potential. This requires commencement of construction in 2022, providing the full ITC benefit and capture of 100 percent bonus depreciation by the PPA Provider.

The assumed allocation of the remaining inflows and outflows is presented below.

Table 28. Summary of Allocation Assumptions

Category	Accrues to:
Initial Capital Investment	
Solar PV	Provider
Battery Energy Storage (4-hr rating)	Provider
Interconnection & Infrastructure Upgrades	Provider
Project Administration/Overhead (30% of hard costs)	Provider
Operating Inflows	
MA SMART Solar Program Incentive Payment	Provider
On-Bill Savings - Demand Charge	Split
On-Bill Savings - Energy Charge	Host
PPA Solar PV Energy Payment from Host to Provider	Provider
Demand Response	Split
Clean Energy Peak Credit-Solar PV	Split
Clean Energy Peak Credit-Battery Storage	Split
Operating Outflows	
Operations & Maintenance Expenses	Provider
Host Solar PV Energy Payment to PPA Provider	Host
Battery Round Trip Energy Loss	Split
Investment Tax Credit	
Depreciation	Provider

Source: Willdan Financial Services, 2021

Split items within the financial analysis are allocated 60 percent to the PPA provider and 40 percent to the City/Host.



Multi-year net cash flows are somewhat lower than the stabilized year figure, reflecting the effects of battery storage and solar PV performance degradation. The estimated net cash flow roundly totals \$687,000 in the first full year, decreasing to \$573,000 in the last full year (in constant value 2021 dollars).

The following assumptions support the cash flow analysis detailed in **Table 29**:

1. Investment Tax Credit percent is 26.0% if construction commences in 2021 or 2022, 22.0% in 2023, and 10.0% thereafter.
2. Battery must receive a minimum of 75% of charging over the entire year from renewable sources; tax credit is then proportioned by the percentage of power 75% or higher.
3. MA Smart Program Incentive duration is 10 years for systems \leq 25 kW AC or 20 years for systems $>$ 25 kW AC.
4. PPA Energy Payment assumes \$0.125 per kWh.
5. Bonus depreciation capture requires all assets to be depreciated under this methodology; if bonus amount is less than 100 percent, any remainder is depreciated under the MCARS schedule.
6. The model assumes zero (\$0) residual value of assets at the end of useful life



Table 29. Statement of Estimated 20-Year Cash Flow

Total Capital Investment: Years 1-10		Yr1	Yr2	Yr3	Yr4	Yr5	Yr6	Yr7	Yr8	Yr9	Yr10
Accrues to:		2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
Effective Capacities/Outputs (assumes degradation over time)											
Solar PV (kW)		349	1,158	1,152	1,147	1,141	1,135	1,130	1,124	1,118	1,113
Battery Energy Storage (4-hr rating) (kWh)		198	653	647	640	634	628	621	615	609	603
Battery Power (KW)		50	163	162	160	158	157	155	154	152	151
Battery Power (MW)		0.05	0.16	0.16	0.16	0.16	0.16	0.16	0.15	0.15	0.15
			1,501,59								
Annual Solar Generation (kWh)		452,741	0	1,494,082	1,486,612	1,479,179	1,471,783	1,464,424	1,457,102	1,449,817	1,442,567
% of Initial Battery Storage Capacity		30.0%	99.0%	98.0%	97.0%	96.1%	95.1%	94.1%	93.2%	92.3%	91.4%
% of Initial Solar PV Output		30.0%	99.5%	99.0%	98.5%	98.0%	97.5%	97.0%	96.6%	96.1%	95.6%
Initial Capital Investment											
Solar PV	Provider	3,387,240	-	-	-	-	-	-	-	-	-
Battery Energy Storage (4-hr rating)	Provider	366,218	-	-	-	-	-	-	-	-	-
Interconnection & Infrastructure Upgrades	Provider	70,000	-	-	-	-	-	-	-	-	-
Project Administration/Overhead (30% of hard costs)	Provider	<u>1,126,037</u>	-	-	-	-	-	-	-	-	-
Total Initial Capital Investment		\$4,949,495	\$-								
Capital Reinvestment											
Solar PV	Provider	-	-	-	-	-	-	-	-	-	-
Battery Energy Storage (4-hr rating)	Provider	-	-	-	-	-	-	-	-	-	-
Project Administration/Overhead (30% of hard costs)	Provider	-	-	-	-	-	-	-	-	-	-
Total Reinvestment		\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-
Total Capital Investment		\$4,949,495	\$-								

Note: Yr1 and Yr21 are partial years
 Source: City of Framingham; Willdan, 2022



Table 29: Statement of Estimated 20-Year Cash Flow, Continued

Total Capital Investment: Years 11-21		Yr11	Yr12	Yr13	Yr14	Yr15	Yr16	Yr17	Yr18	Yr19	Yr20	Yr21
	Accrues to:	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042
Effective Capacities/Outputs (assumes degradation over time)												
Solar PV (kW)		1,107	1,102	1,096	1,091	1,085	1,080	1,074	1,069	1,064	1,058	1,053
Battery Energy Storage (4-hr rating) (kWh)		597	591	660	653	647	640	634	628	621	615	609
Battery Power (KW)		149	148	165	163	162	160	158	157	155	154	152
Battery Power (MW)		0.15	0.15	0.17	0.16	0.16	0.16	0.16	0.16	0.16	0.15	0.15
Annual Solar Generation (kWh)		1,435,355	1,428,178	1,421,037	1,413,932	1,406,862	1,399,828	1,392,829	1,385,865	1,378,935	1,372,041	1,365,180
% of Initial Battery Storage Capacity		90.4%	89.5%	100.0%	99.0%	98.0%	97.0%	96.1%	95.1%	94.1%	93.2%	92.3%
% of Initial Solar PV Output		95.1%	94.6%	94.2%	93.7%	93.2%	92.8%	92.3%	91.8%	91.4%	90.9%	90.5%
Initial Capital Investment												
Solar PV	Provider	-	-	-	-	-	-	-	-	-	-	-
Battery Energy Storage (4-hr rating)	Provider	-	-	-	-	-	-	-	-	-	-	-
Interconnection & Infrastructure Upgrades	Provider	-	-	-	-	-	-	-	-	-	-	-
Project Administration/Overhead (30% of hard costs)	Provider	-	-	-	-	-	-	-	-	-	-	-
Total Initial Capital Investment		\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-
Capital Reinvestment												
Solar PV	Provider	-	-	-	-	-	-	-	-	-	-	-
Battery Energy Storage (4-hr rating)	Provider	-	-	238,818	-	-	-	-	-	-	-	-
Project Administration/Overhead (30% of hard costs)	Provider	-	-	71,645	-	-	-	-	-	-	-	-
Total Reinvestment		\$-	\$-	\$310,463	\$-							
Total Capital Investment		\$-	\$-	\$310,463	\$-							

Note: Yr1 and Yr21 are partial years
 Source: City of Framingham; Willdan, 2022



Table 29: Statement of Estimated 20-Year Cash Flow, Continued

Net Cash Flow after ITC & Depreciation: Years 1-10		Yr1	Yr2	Yr3	Yr4	Yr5	Yr6	Yr7	Yr8	Yr9	Yr10
	Accrues to:	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
Operating Inflows											
MA SMART Solar Program Incentive Payment 3/	Provider	115,396	382,729	380,816	378,912	377,017	375,132	373,256	371,390	369,533	367,685
On-Bill Savings - Demand Charge	Split	24,224	80,137	79,534	78,935	78,341	77,752	77,168	76,589	76,015	75,445
On-Bill Savings - Energy Charge	Host	56,571	187,626	186,688	185,754	184,825	183,901	182,981	182,066	181,156	180,250
PPA Solar PV Energy Payment from Host to Provider 4/	Provider	56,593	187,699	186,760	185,827	184,897	183,973	183,053	182,138	181,227	180,321
Demand Response aka Connected Solutions	Split	14,850	49,005	48,515	48,030	47,550	47,074	46,603	46,137	45,676	45,219
Clean Energy Peak Credit-Solar PV	Split	7,352	24,383	24,262	23,314	22,375	21,446	20,525	19,612	18,709	17,813
Clean Energy Peak Credit-Battery Storage	Split	-	46,590	46,124	44,100	42,112	40,159	38,241	36,358	34,508	32,692
Total Operating Inflows		\$274,985	\$958,170	\$952,698	\$944,871	\$937,118	\$929,437	\$921,828	\$914,290	\$906,823	\$899,426
Operating Outflows											
Accrues to:											
Operations & Maintenance Expenses											
Solar PV	Provider	6,286	20,847	20,743	20,639	20,536	20,433	20,331	20,230	20,128	20,028
Battery Energy Storage (4-hr rating)	Provider	8,910	29,403	29,109	28,818	28,530	28,244	27,962	27,682	27,406	27,131
Total Operations and Maintenance		\$15,196	\$50,250	\$49,852	\$49,457	\$49,066	\$48,678	\$48,293	\$47,912	\$47,534	\$47,159
Host Solar PV Energy Payment to PPA Provider 4/	Host	\$56,593	\$187,699	\$186,760	\$185,827	\$184,897	\$183,973	\$183,053	\$182,138	\$181,227	\$180,321
Battery Round Trip Energy Loss	Split	\$9,864	\$32,655	\$32,433	\$32,212	\$31,994	\$31,777	\$31,561	\$31,347	\$31,135	\$30,925
Total Operating Outflows		\$81,652	\$270,604	\$269,045	\$267,496	\$265,957	\$264,427	\$262,907	\$261,397	\$259,896	\$258,405
Net Operating Cash Flow		\$193,333	\$687,566	\$683,653	\$677,375	\$671,161	\$665,010	\$658,921	\$652,893	\$646,927	\$641,021
Investment Tax Credit											
Accrues to:											
Solar PV Investment Tax Credit (ITC) 1/	Provider	\$1,160,811	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-
Battery Storage Investment Tax Credit (ITC) 1/ 2/	Provider	125,503	-	-	-	-	-	-	-	-	-
Total ITC		\$1,286,314	\$-								
Depreciation 5/											
Accrues to:											
Bonus Depreciation Taxable Basis		3,208,117	-	-	-	-	-	-	-	-	-
Modified Accelerated Cost Recovery System (MACRS) Taxable Basis		-	-	-	-	-	-	-	-	-	-
Depreciation Benefit @ 22% Federal Tax Rate	Provider	705,786	-	-	-	-	-	-	-	-	-
Net Cash Flow after ITC and Depreciation		\$899,119	\$687,566	\$683,653	\$677,375	\$671,161	\$665,010	\$658,921	\$652,893	\$646,927	\$641,021

Source: City of Framingham; Willdan, 2022



Table 29. Statement of Estimated 20-Year Cash Flow, Continued

Net Cash Flow after ITC & Depreciation: Years 11-20		Yr11	Yr12	Yr13	Yr14	Yr15	Yr16	Yr17	Yr18	Yr19	Yr20	Yr21
	Accrues to:	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042
Operating Inflows												
MA SMART Solar Program Incentive Payment 3/	Provider	\$345,597	\$343,869	\$342,150	\$340,439	\$338,737	\$337,043	\$335,358	\$333,681	\$332,012	\$330,352	-
On-Bill Savings - Demand Charge	Split	74,881	74,321	78,429	77,831	77,239	76,652	76,069	75,492	74,919	74,351	73,788
On-Bill Savings - Energy Charge	Host	179,348	178,451	177,564	176,676	175,792	174,913	174,038	173,168	172,302	171,440	170,583
PPA Solar PV Energy Payment from Host to Provider 4/	Provider	179,419	178,522	177,630	176,741	175,858	174,978	174,104	173,233	172,367	171,505	170,648
Demand Response aka Connected Solutions	Split	44,767	44,319	49,500	49,005	48,515	48,030	47,550	47,074	46,603	46,137	45,676
Clean Energy Peak Credit-Solar PV	Split	16,927	16,048	15,178	14,317	13,463	12,618	11,781	10,952	10,131	9,318	8,513
Clean Energy Peak Credit-Battery Storage	Split	<u>30,908</u>	<u>29,157</u>	<u>30,955</u>	<u>29,051</u>	<u>27,182</u>	<u>25,348</u>	<u>23,547</u>	<u>21,780</u>	<u>20,046</u>	<u>18,345</u>	<u>16,675</u>
Total Operating Inflows		\$871,847	\$864,688	\$871,406	\$864,061	\$856,786	\$849,582	\$842,447	\$835,380	\$828,381	\$821,449	\$485,882
Operating Outflows												
Accrues to:												
Operations & Maintenance Expenses												
Solar PV	Provider	19,928	19,828	19,729	19,630	19,532	19,434	19,337	19,241	19,144	19,049	18,953
Battery Energy Storage (4-hr rating)	Provider	<u>26,860</u>	<u>26,592</u>	<u>29,700</u>	<u>29,403</u>	<u>29,109</u>	<u>28,818</u>	<u>28,530</u>	<u>28,244</u>	<u>27,962</u>	<u>27,682</u>	<u>27,406</u>
Total Operations and Maintenance		\$46,788	\$46,420	\$49,429	\$49,033	\$48,641	\$48,252	\$47,867	\$47,485	\$47,106	\$46,731	\$46,359
Host Solar PV Energy Payment to PPA Provider 4/	Host	\$179,419	\$178,522	\$177,630	\$176,741	\$175,858	\$174,978	\$174,104	\$173,233	\$172,367	\$171,505	\$170,648
Battery Round Trip Energy Loss	Split	\$30,716	\$30,508	\$31,654	\$31,436	\$31,220	\$31,006	\$30,793	\$30,582	\$30,373	\$30,165	\$29,958
Total Operating Outflows		\$256,923	\$255,450	\$258,713	\$257,211	\$255,719	\$254,237	\$252,764	\$251,300	\$249,846	\$248,401	\$246,965
Net Operating Cash Flow		\$614,924	\$609,238	\$612,693	\$606,850	\$601,067	\$595,345	\$589,683	\$584,080	\$578,535	\$573,048	\$238,917
Investment Tax Credit												
Accrues to:												
Solar PV Investment Tax Credit (ITC) 1/	Provider	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-	\$-
Battery Storage Investment Tax Credit (ITC) 1/ 2/	Provider	-	-	-	-	-	-	-	-	-	-	-
Total ITC		\$-										
Depreciation 5/												
Accrues to:												
Bonus Depreciation Taxable Basis		-	-	-	-	-	-	-	-	-	-	-
Modified Accelerated Cost Recovery System (MACRS) Taxable Basis		-	-	-	-	-	-	-	-	-	-	-
Depreciation Benefit @ 22% Federal Tax Rate	Provider	-	-	-	-	-	-	-	-	-	-	-
Net Cash Flow after ITC and Depreciation		\$614,924	\$609,238	\$612,693	\$606,850	\$601,067	\$595,345	\$589,683	\$584,080	\$578,535	\$573,048	\$238,917

Note: Yr1 and Yr21 are partial years
Source: City of Framingham; Willdan, 2022



Table 30. 20-Year Cash Flow & Investment Deal Structuring

	Yr1 2022	Yr2 2023	Yr3 2024	Yr4 2025	Yr5 2026	Yr10 2031	Yr15 2036	Yr20 2041
Financial Summary & Investment Analytics								
Estimated Cash Flows								
Total Provider Inflows	\$2,191,943	\$690,498	\$686,636	\$681,365	\$676,141	\$650,708	\$614,434	\$590,748
Total Provider Outflows ¹	<u>(4,970,609)</u>	<u>(69,843)</u>	<u>(69,312)</u>	<u>(68,785)</u>	<u>(68,262)</u>	<u>(65,714)</u>	<u>(67,373)</u>	<u>(64,830)</u>
Net Provider Cash Flow	\$(2,778,665)	\$620,654	\$617,325	\$612,581	\$607,879	\$584,994	\$547,061	\$525,918
Cumulative Provider Cash Flow (\$millions)	\$(2.78)	\$(2.16)	\$(1.54)	\$(0.93)	\$(0.32)	\$2.65	\$5.11	\$7.78
Provider's Total Cumulative 20-Yr Cash Flow	\$7,974,760							
NPV of Provider's Estimated 20-Yr Cash Flow @ 8.25% Discount Rate	\$2,271,827							
IRR of Provider's Estimated 20-Yr Cash Flow	20.8%							
First Year of Positive Cumulative Cash Flow	Year6							
Total Host/City Inflows	\$75,141	\$267,673	\$266,061	\$263,506	\$260,976	\$248,717	\$242,352	\$230,701
Total Host/City Outflows	<u>(60,538)</u>	<u>(200,761)</u>	<u>(199,733)</u>	<u>(198,711)</u>	<u>(197,695)</u>	<u>(192,691)</u>	<u>(188,346)</u>	<u>(183,571)</u>
Net Host/City Cash Flow	\$14,603	\$66,912	\$66,328	\$64,794	\$63,282	\$56,027	\$54,006	\$47,130
Cumulative Host/City Cash Flow (\$millions)	\$ 0.01	\$ 0.08	\$ 0.15	\$ 0.21	\$ 0.28	\$0.57	\$0.84	\$1.1
Host's Total Cumulative 20-Yr Cash Flow	\$1,139,621							
NPV of Host's 20-Yr Estimated Cash Flow @ 3.00% Discount Rate	\$816,836							

¹ Assumes Provider reinvests total value of initial capital in Year 14 at the end of equipment's estimated useful life.
Source: City of Framingham; Willdan, 2022



5.12 Financial Analysis Conclusions

The allocations of inflows and outflows indicate strong financial positions for both the PPA provider and the City/Host. The PPA provider’s internal rate of return (assuming an all-cash deal) equates to 20.8 percent and a net present value of \$2.23 million, calculated using a discount rate of 8.25%.

The City’s cash flow over the 20-year term is estimated at \$1.1 million, generating a net present value of \$816,000, when discounted at a rate of 3.0 percent annually. This discount rate reflects the relatively lower cost of capital typically available to a public entity.

5.13 Financial Sensitivity Analysis

What represents an acceptable rate of return to either party in a PPA deal is a difficult figure to isolate, as motivations and risks are all measured and valued differently by those involved. This question is the basis for negotiation. Yet to negotiate effectively, it is helpful to understand the various drivers that can be modified and their impact on financial returns.

The financial analysis is based on the primary objective to solve for a PPA provider return of 12 percent, a purely theoretical assumption for planning purposes only. It is unlikely that any negotiation would focus on just a single assumption, but rather a combination of adjustments that identify mutually beneficial returns and other benefits to each of the parties. The following table provides the results of financial sensitivity analyses of the impact of a broad range of variables on the relative negotiation position of each party.

Variable	Financial Feasibility Impact
Capital Costs	Capital expenditures could increase by 49%
Split to City:	The allocation of “split” revenue and expense items could increase to 100 percent to the City/host versus the modeled 40 percent, generating an estimated internal rate of return of 16.8% to the provider.
PPA Energy Price:	PPA energy price could decrease to -\$0.008 per kWh (indicating a payment to the host), highlighting the relatively substantial benefits of the SMART Solar Program and federal tax incentives
Battery Useful Live	Battery useful life is estimated at 12 years, requiring one reinvestment cycle over the 20-year term that is modeled to accrue to the PPA provider. Reduction of the useful life to 10 years and the addition of a second replacement cycle at the end of the 20-year term would reduce the provider’s estimated internal rate of return by 0.2%, to 20.56 %.

Importantly, future expansion or modification of existing programs, implementation of new incentives, grants, and other financial enhancements are possible but not modeled. Preservation of rights to these benefits, carbon credits, and other efforts to monetize environmental benefits may be additional points of consideration and sources of negotiation.

6. Conclusion

The City of Framingham’s Winch Park CLEAR study demonstrates both technical and financial options to solve threats to the municipal assets in the community. The threats to the infrastructure are both climate change and human-created disasters. Energy is essential to municipal operations and basic constituent



services. Resilient solutions are needed to carry the City of Framingham through interruptions to the power grid in the region.

For this resiliency community study funded by MassCEC, the technical team first met with all the stakeholders to understand their current energy asset reliability concerns to meet future resiliency needs. An RFI and a resiliency questionnaire were issued to collect key data informing both the technical and financial solutions.

The responses further informed the technical team's knowledge of each stakeholder's assets and resiliency priorities. Finally, site visits with the help of the City and stakeholders allowed the technical team to visualize each site's opportunities and threats.

State-level and local relevant Regulations, Definitions, and Assumptions related to this study report were presented. The collected energy data and energy system information from both the stakeholders and utility were reviewed and analyzed. The requested information and resiliency questionnaire responses are reviewed, together with the utility and stakeholders. The technical team met with all the stakeholders monthly to understand their current energy asset reliability concerns to meet future resiliency needs.

A preliminary technical design and system configuration was proposed for WPMRS, in accordance with the findings of the site assessment and characteristics identified in the site assessment. The proposed microgrid infrastructure and operations were presented in which the PCCs were identified. The load characteristics of different stakeholders and aggregated hourly load profiles for WPMRS were presented.

The estimated hourly, daily and monthly load profiles were presented for evaluation by WPMRS stakeholders. The proposed DERs planned to be operated in the WPMRS were also discussed. The current and proposed electrical and thermal infrastructure were presented, along with the preliminary configurations for the proposed system.

The characterization of the WPMRS master controller and services and benefits provided by the proposed community microgrid were described. The information technology and telecommunication infrastructure necessary for the proposed microgrid solutions were discussed.

Based on these key WPMRS investment and operating parameters, the current annual energy costs and CO₂ emissions for the existing loads were calculated to be \$0.760 thousands and 1,454 metric tons, respectively. This represents the baseline for the proposed microgrid solution. The proposed community microgrid would have 43.4% annual cost savings compared with the base case, and 21% annual saving on CO₂ emissions. The annual CO₂ emission reduction is 303 metric tons.

To utilize federal/state tax incentives such as ITCs on the proposed solar and battery storage installations, an owner must have a tax liability. The proposed community microgrid could be owned jointly by the stakeholders, a third-party investor, or partly owned by a public utility (e.g., battery storage).

Since all the stakeholders are public, a third-party special-purpose entity (WPMRS Co.) will likely be developed to own and manage the microgrid. The microgrid participants would subsequently draft and enter into long-term agreements (the Power Purchase Agreement) to purchase energy from the microgrid owner/operator.

The financial analysis assumes a third-party PPA funding model, wherein the PPA provider would build and maintain the new generation assets and the community microgrid.



The financial analysis and allocations of City (Host)/PPA inflows and outflows indicate strong financial positions for both the PPA provider and the City (Host).

The PPA provider's internal rate of return (assuming an all-cash deal) equates to 20.8 percent and a net present value of \$2.23 million, calculated using a discount rate of 8.25%.

The City's cash flow over the 20-year term is estimated at \$1.1 million, generating a net present value of \$816,000 when discounted at a rate of 3.0 percent annually.

The City of Framingham can demonstrate a working community microgrid in Massachusetts.



Appendix A: Financial Analysis – Glossary of Terms

The following key terms (and their acronyms) are defined to inform audiences with limited technical training related to the development of microgrids and their component distributed energy sources (DERS).

Battery Storage

Battery technology is rapidly changing and evolving. Currently, two technologies are poised to dominate the near-term landscape for large-scale commercial applications: Lithium-ion (Li-ion) and Vanadium (V-flow). Older technologies, such as lead/acid (car battery), and nickel/cadmium or NiCad (laptops and camcorders), have either been displaced from or are not viable for commercial storage applications.

One of the key attributes of batteries, aside from basic storage/use, is the ability to displace consumption of high cost/peak demand energy (peak shaving) with energy stored from renewable sources (best) or grid energy produced during lower cost/demand periods during the day or night (better). Another benefit is the instantaneous responsiveness of batteries to support energy needs, either locally or within the broader electrical grid.

Battery lifetimes typically range from 5 to 15 years. Warranties and lifetimes are typically tied to a specific number of recharging cycles or when a battery will only charge to 70 percent of the original nameplate capacity. Battery capacity also degrades over time, with storage losses of typically between one-half (0.5%) and two percent (2.0%) per year.

Capital planning must consider battery replacement costs for longer-term projects, especially if the functional lifetime is closer to 10 years than 15. The good news here is that the future cost to replace may be lower for the same quantity of energy storage. Pricing per kWh of storage has decreased at an average rate of eight (8) percent over the past several years. Forward-looking estimates anticipate annual price reductions ranging between 2.5 percent and 9.2 percent per kW through 2030, and smaller but continuous annual reductions through 2050 (1.3%-2.7%).

Improved design and increased manufacturing capacity, competition and innovation are the primary forces driving lower prices. For illustrative purposes, a \$100 battery today could cost less than \$50 in 15 years (current year dollars), assuming a five percent (5.0%) average annual price decrease.

Black Start Support

A black start is the process of restoring an electric power station or a part of an electric grid to operation without relying on the high-cost external electric power transmission network to recover from a total or partial shutdown. When available, hydroelectric power sources represent an excellent source of black start capacity due to the low power requirements to bring that asset online, which through a series of steps, can then restart the other power plants in the system. Stored battery power is similarly poised to serve in this capacity, requiring no “startup” and instantaneous responsiveness potential.

Clean Peak Energy Credits (CPEC)

The Clean Peak Standard (CPS) is designed to provide incentives to clean energy technologies that can supply electricity or reduce demand during seasonal peak demand periods established by DOER.



Under the program, all retail electric suppliers in Massachusetts are required to procure a minimum percentage of total annual electricity sales to Massachusetts end-use customers from Clean Peak Resources by either purchasing CPECs or retiring earned CPECs. Starting at 1.5% of retail electricity sales in 2020, the minimum requirement increases over time by at least 1.5% each year, to a target of 16.5% in 2030 and 46.5% in 2050. The program will expire in 2050, unless extended by law.

The value of a CPEC is set annually, based on the total megawatts (MW) of energy produced by qualified units. As of January 2021, the Commonwealth identified 17 qualified resources generating just under 37 MW of energy (nameplate capacity). DOER utilizes monthly reported peak to identify when the Actual Monthly System Peak Multiplier should adjust the number of Clean Peak Energy Certificates.

The value of each CPEC, while variable, is effectively capped by a provision that allows the retail electric supplier to satisfy their Clean Peak Standard's minimum requirement via an alternative compliance payment ("ACP").

The initial ACP rate is \$45.00 per MWh through the 2024 compliance year. Thereafter, it is programmed to decline by \$1.54 per MWh each year through 2050. Adjustments to the automatic ACP reduction are tied to the market supply of CPECs. If the supply is greater than the targeted level during the program year, the ACP rate reduction would be larger in the following year.

Demand Response (Active and Passive)

There are two types of demand response resources: active and passive, each with its own revenue implications.

Active demand resources comprise what is commonly referred to as Demand Response (DR). ISO-NE has two branded programs – Daily Dispatch and Connected Solutions. These programs both provide payments for being on [active] stand-by to be "called" to lower energy usage when the power grid is anticipated to be stressed or when the risk of failure is too high. This could include customers powering down equipment or switching to an alternative energy source, such as a generator or battery storage. Participants typically receive one-day notification for events that occur most often in July and August for events that last two to three hours.

Under the "active" DR Program, assets under 5 MW are consolidated or "mapped" into larger blocks referred to as Demand-Response Resources. Assets over 5MW comprise their own resource. These "resources" are then the direct participants in the DR program that comprise a small portion of the ISO's overall supply obligations. The market price for active DR varies by location and seasonally. Demand response was valued by Eversource at \$200 per kW in the New England market for summer 2020.

Summer peak hours are non-holiday weekdays, 1:00 p.m. to 5:00 p.m., June, July, and August. Winter peak hours are non-holiday weekdays, 5:00 p.m. to 7:00 p.m., December and January. Participation can be limited to the summer months only. Benefits would be reduced by two-thirds under this option.

Seasonal-peak resources provide the same attributes as on-peak resources, but only during the summer months of June, July, and August, and the winter months of December and January, during those hours on non-holiday weekdays when the real-time system hourly load is equal to or greater than 90 percent of the system peak-load "50/50" forecast (50% chance of exceeding the calculated peak load for a New England-wide summer temperature of 90.2°F, and winter temperature of 7.0°F).



Passive demand resources (DR-P) are principally designed to save electricity and cannot be altered or “called” by a dispatch instruction. Examples include energy-efficient appliances and lighting, advanced cooling and heating technologies, and passive behind-the-meter generation, such as solar power. Passive demand resources can only participate in the On-Peak or Seasonal-Peak capacity markets.

Consolidated Heat and Power (CHP)

Consolidated Heat and Power, or cogeneration, is the concurrent production of electricity or mechanical power and the capture of by-product thermal energy from a single source of energy, typically near a point of consumption. CHPs can use a variety of fuels, both fossil- and renewable-based and a variety of technologies (gas turbines, microturbines, reciprocating engines, steam turbines, absorption chillers, and fuel cells). Generally, CHPs deliver energy at an efficiency of 65-75 percent versus a national average of 50 percent when the services are provided separately.

Curtailement Service Providers (CSP)

Curtailement Service Providers are organizations that, through a contractual arrangement, manage Demand Response (DR) programs. Commonly referred to as aggregators, these independent firms market DR opportunities, size the DR opportunity, manage curtailement events/communications, and calculate payments and underperformance penalties. The fee for this service typically ranges between 20 and 40 percent of the benefit amount.

Curtailement

Curtailement is the deliberate reduction in output (below what could have been produced) to address the interconnected issues of oversupply, reliability issues arising from excess energy production, and market pressure to lower pricing, in some instances to negative values.

While several types of curtailement exist, “economic dispatch” (due to low market price) is by far the most common. It is a self-scheduled response to a call for less generation for a fee.

Depreciation

Depreciation is an accounting reduction in the value of an asset with the passage of time. In the simplest application, depreciation would reflect wear and tear and an asset’s useful life. Internal Revenue Service (IRS) rules establish rules for the capture of depreciation, at times setting asset schedules that do not align with the anticipated useful lifetime, primarily as an investment incentive. These accelerated schedules increase the capture of depreciation early in the investment horizon, providing a source of savings on federal income taxes. The amount of tax savings, however, is dependent on the effective federal tax rate of the ownership entity.

Under the Investment Tax Credit (see ITC) legislation, two methodologies for depreciation are available: Bonus and Modified Accelerated Cost Recovery System (MCARS).

Under the Bonus depreciation schedule, solar systems placed in service between January 1, 2018, and December 31, 2022, can elect to claim a 100% bonus depreciation of capital equipment in that tax year. Starting in 2023, the percentage drops 20% per year (e.g., 80% in 2023 and 60% in 2024) until the provision drops to 0% in 2027. If the ITC is claimed, the depreciable basis of the asset(s) is decreased by one-half of the ITC amount received (see ITC).



Important considerations when selecting the bonus depreciation methodology are rules requiring that all assets must be placed in the bonus depreciation pool and that assets must be owned for at least six years to fully vest the benefits. If the assets are not held for the duration, the paid tax benefits would be subject to recapture.

Alternatively, under the MCARS methodology, solar PV with associated battery storage could be depreciated under the 5-year Property, Half-Year Convention schedule. The annual amount of capital investment calculated for depreciation would follow this schedule:

Year	Value of CapEx Depreciation
Year 1	20.00%
Year 2	32.00%
Year 3	19.20%
Year 4	11.52%
Year 5	11.52%
Year 6	5.76%

Source: U.S. Department of Energy; Willdan, 2021

This schedule would also apply to any amount not captured by the bonus depreciation (i.e., if 60 percent taken under the bonus rules, then remaining 40 percent could use the MCARS methodology). As with the bonus depreciation option, the actual benefit would equate to the depreciable amount times the effective corporate tax rate.

Solar PV, without the associated battery component, would be subject to a 7-year depreciation schedule. Current full text documentation can be found at: <https://www.energy.gov/eere/solar/articles/residential-and-commercial-itc-factsheets>.

Distributed Energy Resource (DER)

Distributed energy resources are the physical and virtual energy assets that are deployed across a distribution network and comprise a microgrid. Physical assets typically include solar PV, battery storage, and less frequently consolidated heat and power and wind turbines. Inclusive in this definition is the technology that connects the assets to the bulk energy system (typically referred to as the “electric grid”) and the controls that allow for participation in secondary energy market opportunities (e.g., demand response, peak shaving)

Forward Capacity Market (FCM) Savings

The Forward Capacity Market (formerly referred to as the Installed Capacity Market) is a long-term wholesale electricity market that ensures resource adequacy, locally and systemwide, through an auction process that typically runs three years prior to the commitment year. This longer horizon helps ensure that future resource needs will be met, and if not, that market forces will encourage participation prior to that need.

Capacity resources may be new or existing and may include energy supply from generators, imported capacity, or demand capacity resources that reduce electricity consumption. Added resources must undergo a qualification process that ensures the future availability of committed supply. Annual and monthly “reconfiguration auctions” provide opportunities for the ISO to shed excess obligations or add additional ones.



Frequency Regulation

This is the effort to maintain electrical grid stability by ensuring all the energy generators are spinning at the same frequency, typically at 60 Hertz (Hz). Frequency is measured by the rate of spin per second and the definition of the term Hertz (Hz). Grid operators must maintain very tight thresholds on grid frequency to maintain stability.

Imbalance occurs when a sudden production surge (imagine a wind gust on a wind farm) suddenly supplies the grid creating an over-frequency event. Alternatively, a power plant goes offline and creates an under-frequency event. Over-frequency events are typically less problematic to solve, and automatic sensors typically kick in to reduce output.

Under-frequency events are inherently more challenging. Increasing production may require a dispatch call to a large power plant that requires time to adjust output. Storage batteries are very advantageous because they can be called to respond almost immediately to frequency regulation requests, responsiveness that grid operators value. However, small- or mid-scale energy storage on the distribution grid can run into challenges in the Frequency Regulation market due to the attendant costs of the telemetry equipment required to participate. Participating in the frequency regulation market requires a set aside for a fixed amount of capacity that would not be available for the day-ahead/real-time energy market.

Installed Capacity Reduction (ICAP)

ICAP management is a customer-centric savings mechanism that is tied to consumption by commercial uses. Programs often utilize an online service that presents a predictive model to alert customers when the grid demand is likely to peak. This knowledge provides an opportunity to proactively lower energy usage during the annual system peak-hour (aka “coincident demand”).

This peak-hour figure sets the value of an Installed Capacity Tag (ICT) that drives the following year’s capacity charges, a figure that accounts for 20 to 30 percent of the electric bill. Participants are required to have an interval meter (records electricity consumption every 30 minutes) with an ICT. Energy providers assign tags once annually, following the assessment period that runs from June 1st to May 31st.

Investment Tax Credit (ITC)

The U.S. government currently offers a credit that can be claimed on federal corporate income taxes (i.e., not available for tax-exempt entities like charities) against the capital cost (purchase, install, and related equipment and soft costs) for new commercial solar photovoltaic systems and associated battery storage. In December of 2020, Congress extended the ITC to provide a federal tax credit of 26 percent of costs for systems commencing construction in 2020, 2021, or 2022, 22 percent in 2023, and 10 percent thereafter.


The battery portion of the tax credit is subject to a further reduction based on the percentage of stored energy produced by a renewable source (e.g., Solar PV generates 80% of stored battery energy, then the credit is reduced to 80 percent of capital cost). Importantly, the renewable source must generate at least 75 percent of the stored battery energy, or the tax credit is eliminated entirely.

Independent Service Operators (ISO)

Independent Service Operators (and their cousin Regional Transmission Operators or RTOs) operate the electricity transmission system and foster competition among market producers. ISOs establish and



manage energy and related-service markets that use bid-based systems to optimize electricity output from generation facilities to meet current and future system loads at the lowest possible cost. While major sections of the southeast and west operate under more traditional wholesale market structures, two-thirds of the nation’s electricity load is served within ISO/RTO regions.



Kilowatt (kW) and Megawatt (MW)

A kilowatt is a unit of power. One megawatt equals 1,000 kW. These figures represent the size of the discharge flow. A common analogy is a gas can. The size of the spout opening dictates how fast the gasoline can be poured out of the can. The kW or MW rating is the same, but for electricity.

Kilowatt-hour (kWh) and Megawatt-hour (MWh)

A kilowatt-hour is a unit of energy capacity. One megawatt-hour equals 1,000 kWh. A common analogy, again using the gas can analogy (see kW and MW), would be the quantity of fuel that is contained.

Local Property Tax Exemptions



Solar energy systems used as a primary or auxiliary power system for the purpose of heating or otherwise supplying the energy needs of taxable property may be exempt from local property tax for a 20-year period. This incentive requires the system owner to enter into an agreement with the city or town to provide a payment in lieu of taxes (PILOT) that equals at least 5 percent of its gross income during the prior calendar year.

The incentive applies only to the value added to a property by an eligible system and the components used exclusively by that system. It does not constitute an exemption for the full amount of the property tax bill.

Solar facilities that generate electricity to sell to the grid may be eligible for a Tax Increment Financing exemption agreement if they are in an Economic Opportunity or Economic Target Area. Facilities owned by electric generation or wholesale generation companies may be eligible for a payment in lieu of a tax agreement.

Changes to the exemption rules enacted under SB-9:

- Requires that an exempt project produce not more than 125 percent of the annual electricity needs of the property on which it is located, including non-contiguous real property within the same municipality in which there is a common ownership interest
- Limits the size of the eligible system to 25kW or less
- Overrules a prior decision to allow exemptions for a solar project located in one town that allocated bill credits to taxable properties in an adjacent town
- Extends the exemption to solar projects that “supply the energy needs” of property owned by tax-exempt nonprofit entities such as government buildings, schools, universities, nonprofit hospitals and other similar entities so long as the projects meet the 125 percent limitation across the entire campus
- Expands the exemption and PILOTs to include energy storage and fuel cells
- Standardizes the assessment process, terminology, terms, and tax policies across the Commonwealth

Regional Network Services (RNS)

Regional Network Service (RNS) is the transmission service to move electricity that transmission customers purchase to serve their network load in the New England Control Area.

Reliability

Reliability is achieved through the design, operation and maintenance of power supply to provide an adequate, safe and stable flow of electricity.

The ISO-NE has a Reliability Committee (RC) that is responsible for the design and oversight of reliability standards for the power system in New England. This committee focuses on short-term and long-term load forecasts to meet regulatory standards, the collection and exchange of system data for the future, standards and procedures to maintain a reliable and efficient power system in New England, plans for supply and demand-side resources, transmissions, and interconnections, procedures for dispatch infrastructure, and installed capacity requirements and ISO determinations on capacity requirements.



Resiliency

Resilience is directly linked to the concept of reliability, as a system cannot be resilient if it is not reliable. Resilience, however, is broader and tied to the preparation, operation, and subsequent recovery from significant events. It is also the ability to withstand extreme or prolonged events.

Resilience, from an energy perspective, is about ensuring a business has a reliable, regular supply of energy and contingency measures in place in the event of a power failure. Causes of resilience issues include power surges, weather, natural disasters, accidents and even equipment failure. The human operational error can also be an issue and should be factored into resilience planning. Ensuring a business is resilient may help insulate against energy price increases or fluctuations in supply and avoid delays or shutdown of their important processes that impact their ability to deliver goods or services. And while most power outages are shorter term in nature, there is a clear trend in the increasing number of large-scale natural weather events that can have broader, longer-term impacts. Critical industries, such as health care, senior centers, emergency services, and other critical industries will certainly become less susceptible to significant impacts as the resilience of the energy system improves.

Round Trip Energy Costs

Round trip energy costs reflect the net expense associated with recharging a battery storage energy resource. The expense reflects the fact that the amount of energy needed to charge a battery is more than the amount of energy that is discharged.

SMART Solar Incentives

The Solar Massachusetts Renewable Target (SMART) Program is a long-term sustainable solar incentive program operated by the Massachusetts Department of Energy Resources (DOER) with sponsoring electric utilities Eversource, National Grid and Unitil²⁹. The program started in 2018 as a replacement for the Solar Renewable Energy Certificate (SREC) program. The programs' goal is to incentivize the development of 3,200 MW of solar generation in the Commonwealth.

The program pays participating photovoltaic system owners fixed incentive compensation rates for either 10 years (for ≤ 25 kW AC) or for 20 years (for >25 kW AC). Variations to the incentive amounts depend upon location (i.e., behind the meter or within the home or building) and how the system is metered (net metering, quality facility tariffs, or alternative on-bill credit mechanism).

Additional incentive variables include the size of the system, the utility company, and the Capacity Block Compensation Rate (CPCR) set for the utility. The CPCR reflects the goal to encourage the development of "blocks" of solar energy within each of the respective energy company's operating districts, with set-asides for smaller installations (<25 kW).

In addition to the base incentive rates, "adders" are provided to encourage solar development in certain settings (e.g., brownfield, building mounted, canopy, eligible landfills, agricultural), the inclusion of energy storage, and solar tracking capabilities. Off-taker (end-user) adders are available for solar installations that serve low-income areas, provide community shared resources, and serve public entities. Full

²⁹ <https://masmartsolar.com/>



program details, guidelines, and an incentive calculator can be found on the SMART program website (<https://masmartsolar.com/>).

Solar Photovoltaic (PV)

Photovoltaic technology (e.g., solar panel) converts light energy into electricity. In this case, that light source is the sun, thus solar. Solar arrays do degrade over time, with production losses typically averaging between 0.5 and 1.0 percent per year.



Appendix B: State & Federal Grant Programs, Incentives, and Capital Enhancements

The following State & Federal grant programs and other capital enhancements are defined to inform audiences with limited technical training about the universe of potential funding sources available to public and private microgrid investors. These resources may or may not be applicable to the technical solutions under consideration by the City of Framingham, depending on the ultimate renewable energy system and associated funding mechanism implemented by the City.

Biden Bipartisan Infrastructure Framework

When fully implemented, the federal government’s recently passed infrastructure legislation represents a potentially significant source of funding for energy and related infrastructure projects. The framework identifies total funding of \$1.2 trillion, allocated within three broad utility, transportation, and pollution remediation categories. Bringing projects closer to a “shovel-ready” status may be an important attribute to secure funds as they are allocated.

Utility Investments	Total \$ (Billions)
Power Infrastructure	\$73
Broadband	\$65
Water Infrastructure	\$55
Resilience	\$47
Western Water Infrastructure	\$8
Subtotal	<u>\$240</u>

Transportation Investments	Total \$ (Billions)
Roads and Bridges	\$110
Railroads	\$66
Public Transport	\$39
Airports	\$25
Ports and Waterways	\$17
Electric Vehicles	\$15
Road Safety	\$11
Reconnecting Communities	\$1
Subtotal	\$284

Pollution Remediation	\$21 B
------------------------------	---------------

Building Resilient Infrastructure and Communities (BRIC) Grants

BRIC Grants provide states, local communities, tribes and territories funding for eligible mitigation activities that build a culture of preparedness, thus reducing disaster losses and protecting people and property from disasters. Total funding in FY2020, the most recently completed cycle, totaled \$700 million.



Under this program, each state must designate an agency to serve as the Applicant for BRIC funding to submit a single application to FEMA. An application can be made up of an unlimited number of subapplications. Local governments, including cities, townships, counties, special district governments, state agencies, and tribal governments, are considered subapplicants.

Subapplicants must have a FEMA-approved Hazard Mitigation Plan by the application deadline and at the time of obligation of grant funds for mitigation projects and Capability and Capacity Building activities (C&CB).

Projects must:

- Be cost-effective
- Reduce or eliminate risk and damage from future natural hazards
- Meet either of the two latest published editions of relevant consensus-based codes, specifications, and standards
- Align with the applicable hazard mitigation plan
- Meet all environmental and historic preservation (EHP) requirements

In 2018, Massachusetts received a BRIC Grant support funding of the State Hazard Mitigation and Climate Adaptation Plan (SHMCAP). The plan was the first all-hazard mitigation plan that integrated climate impacts and adaptation strategies to address two primary hazards: coastal flooding and winter storm impacts. The planning process was managed through the Executive Office of Energy and Environmental Affairs (EOEEA), the Executive Office of Public Safety and Security (EOPSS), and the Massachusetts Emergency Management Agency (MEMA). Additional background on the BRIC Grant Program and the full case study description of SHMCAP and other successful subapplicants can be found on the FEMA website ([FEMA Hazard Mitigation Action Portfolio](#)).

The fiscal year 2021 (FY 2021) application period for the Hazard Mitigation Assistance (HMA) Notices of Funding Opportunities (NOFOs) for the Building Resilient Infrastructure and Communities (BRIC) grant programs opened on Sept. 30, 2021. This annual application cycle closes at 3 p.m. EST on Jan. 28, 2022.

DOE Loan Guarantees (Title 17 Innovative Energy Loan Guarantee Program)

The Loan Programs Office (LPO) has facilitated more than \$40 billion in loans to deploy large-scale energy infrastructure projects in the United States. Over the past decade alone, LPO has participated in more than \$30 billion of investment across a variety of energy sectors. Like Green Banks, the DOE’s role in financial transactions is one of facilitation, providing financial guarantees that lower the risk for private capital sources.

The LPO's typical role is to bridge financing gaps in the commercial debt market when innovative technologies may not be well understood by the private sector. Project types often include large-scale commercial energy projects, research-development-and-demonstration (RD&D) projects, and smaller projects as well.

Current loan guarantee authorities include:

- \$8.5 billion in for innovative advanced fossil energy projects
- \$10.9 billion in loan guarantee authority for innovative advanced nuclear energy projects
- \$17.7 billion to support U.S. manufacturing of fuel-efficient, advanced technology vehicles



- \$4.5 billion for innovative renewable energy & efficient energy projects
- \$2 billion in partial loan guarantee authority for tribal energy development projects.

Basic eligibility requirements include:

- A new or significantly improved technology
- Reduction or sequestration of greenhouse gases
- Location in the United States
- Expectation for repayment

Additional information can be found at <https://www.energy.gov/lpo/application-process>

EPA Grants

The EPA has several grant opportunities for green infrastructure.

EPA Clean Water State Revolving Fund (CWSRF)—The CWSRF program is a federal-state partnership that provides communities a permanent, independent source of low-cost financing for a wide range of water quality infrastructure projects, including stormwater and green infrastructure.

EPA Office of Wetlands, Oceans, and Watersheds (OWOW) Funding—OWOW has created this website to provide tools, databases, and information for practitioners that serve to protect watersheds.

EPA Brownfields Grant Program—EPA's Brownfields program provides direct funding for Brownfields assessment, cleanup, revolving loans, and environmental job training. To facilitate the leveraging of public resources, EPA's Brownfields Program collaborates with other EPA programs, other federal partners, and state agencies to identify and make available resources that can be used for Brownfields activities.

<https://www.epa.gov/green-infrastructure/green-infrastructure-funding-opportunities>

Green Bonds

A green bond (climate bond) is a type of fixed-income instrument that is specifically earmarked to raise money for climate and environmental projects. These bonds are typically asset-linked and backed by the issuing entity's balance sheet, so they usually carry the same credit rating as their issuers' other debt obligations.

Green bonds come with tax incentives such as tax exemption and tax credits, making them a more attractive investment compared to a comparable taxable bond. These tax advantages provide a monetary incentive to tackle prominent social issues such as climate change and a movement toward renewable sources of energy. To qualify for green bond status, they are often verified by a third party such as the Climate Bond Standard Board, which certifies that the bond will fund projects that include benefits to the environment.

Green Banks

Green Banks are public, quasi-public or non-profit entities established specifically to facilitate private investment into domestic low-carbon, climate-resilient infrastructure. They are publicly capitalized, and their efforts are mission-driven (versus profit-driven) that use financing to accelerate the transition to clean energy and address the impacts of climate change. Additional components of Green Bank missions may include elements that support equity and low-income communities. Green Bank capital is most often



leveraged to attract private capital into deals by de-risking deal terms through credit guarantees and other financial means.

Massachusetts Clean Water Trust

The Massachusetts Clean Water Trust (the Trust) is a state agency that improves the water quality throughout the Commonwealth by providing low-interest loans to municipalities and other eligible entities. This program may be relevant to microgrid projects serving water and water treatment infrastructure.

According to the 2020 Green Bond Report, the Trust:

- Helps communities build or replace water quality infrastructure that enhances ground surface water resources, ensures the safety of drinking water, protects public health, and develops resilient communities.
- Provides low-interest loans and grants to cities, towns, and water utilities through the Massachusetts State Revolving Funds (SRF)
- \$7.6 billion in water infrastructure projects financed from \$2.6 billion in federal grants and state matching funds
- \$998.4 million bonds issued as Green Bonds

Eligible Projects:

- Wastewater treatment projects
- Infiltration/inflow and sewer system rehabilitation projects
- Collector and interceptor sewer projects
- Combined sewer overflow (CSO) correction projects
- Non-point source (NPS) sanitary landfill
- Planning projects – developing plans to address water quality and related public health problems
- Drinking water treatment projects
- Drinking water transmission and distribution projects
- Drinking water source and storage projects
- Drinking water planning and design projects

